



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

NOV - 8 2024

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No					
Name LARRY KINN				Was Well Disinfected Upon Completion? ☒ Yes ☐ No					
Address Dawson, ND.				WATER LEVEL					
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 26					
		County Kidder		GPS 211754		If Flowing, Closed-In Pressure In PSI			
		1/4 46 52	1/4 51 N	1/4					
		Township 49 42	Range 137 W	Section 1					
PROPOSED USE 13907201DCR				WELL TEST DATA					
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☒ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other					
METHOD DRILLED				Pumping Level Below Land Surface					
☐ Cable ☐ Jetted ☐ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After 2					
WATER QUALITY Was a water sample collected for				Hrs. Pumping 5					
Chemical Analysis? ☐ Yes ☐ No				GPM 80					
Bacteriological Analysis? ☐ Yes ☐ No				Feet After					
If So, To What Laboratory Was It Sent?				Hrs. Pumping					
WELL CONSTRUCTION				GPM					
Diameter Of Hole In Inches 18		Depth In Feet 213		WELL LOG					
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				Formation		Depth (ft.)			
Pipe Weight 5DR21		Diameter 12		From 2		To 152			
lb/ft		inches		feet		feet			
lb/ft		inches		feet		feet			
lb/ft		inches		feet		feet			
Was A Well Screen Installed? ☐ Yes ☐ No				topsoil - 20' to 25'					
Was Perforated Pipe Used? ☒ Yes ☐ No				sandy clay					
Screen Or Perforation Interval		From In Feet		To In Feet		sand - dark coarse			
Was Casing Left Open End? ☒ Yes ☐ No				clay til gray					
Material		Diameter In Inches		clay til gray softer					
Slot Size 0.32		Set From In Feet 153		To In Feet 213		sand - blue gravel dark			
Slot Size		Set From In Feet		To In Feet		clay lens			
Was Packer Or Seal Used? ☐ Yes ☒ No				gravel fine to medium					
If So, What Material		Depth In Feet		clay - gray					
Type Of Well ☒ Straight Screen ☐ Gravel Packed				Use Separate Sheet If Necessary					
Depth Grouted 30		From 0		To 30		DATE COMPLETED Aug 5, 2024			
Grouting Material Cement		Other DB chips		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No					
If Other, Explain:				If So, How					
Well Head Completion: Pitless Unit				REMARKS					
12" Above Grade		Other (Specify)		406pm / ft drawdown					
It Other, Specify				DRILLER'S CERTIFICATION					
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.				Driller's Or Firm's Name Larry Kinn					
Certificate Number 81				Address Dawson					
Signed By Larry Kinn				Date 10/18/29					