STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE. DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

RECEIVED
DEC 13 2024
ND DEPT. OF WATER RESOURCES

1. WELL OWNER

Name: Sargent Central School

Address: 515 5th St SW, Forman ND 58032

2. WELL LOCATION

Sketch map location must agree with written location.

GPS _____

EL 13005601ACC

NORTH

1 MILE

Sec. (1 mile) _____

County: Sargent

SW 1/4 SW 1/4 NE 1/4 Sec. 1 Twp. 130N N.Rg 56 W.

3. PROPOSED USE

☐ Domestic ☐ Stock ☐ Geothermal ☑ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☑ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify _____

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☑ No

Bacteriological Analysis? ☐ Yes ☑ No

If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION

Diameter of hole 6 7/8 inches. Depth 175 feet.

Casing: ☐ Steel ☑ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other

If other, specify _____

Pipe Weight:	Diameter:	From:	To:
200 lb/ft	4 inches	0 feet	162 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☐ Yes ☑ No

Perforated pipe set from _____ ft. to _____ feet

Was casing left open end? ☐ Yes ☑ No

Was a well screen installed? ☑ Yes ☐ No

Material PVC Diameter 4 inches

Slot Size 40 set from 162 feet to 172 feet

Slot Size _____ set from _____ feet to _____ feet

Was packer or seal used? ☐ Yes ☑ No

If so, what material _____ Depth _____ ft.

Type of well: Straight screen ☑ Gravel packed ☐

Depth grouted: From 0 To 80

Grouting Material: Cement _____ Other Bentonite

If other, explain: 4 bags Quick-grout 64 gals water

Well head completion: Pitless unit NO

12" above grade yes Other _____

If other, specify _____

Was pump installed? ☑ Yes ☐ No

Was well disinfected upon completion? ☑ Yes ☐ No

7. WATER LEVEL

Static water level 72 feet below surface

If flowing: closed-in pressure _____ psi

GPM flow _____ through _____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify _____

8. WELL TEST DATA

☐ Pump ☐ Bailer ☑ Other Air

Pumping level below land surface:

100 ft. after 1 hrs. pumping 40 gpm

_____ ft. after _____ hrs. pumping _____ gpm

_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Topsoil	0	2
yellow clay	2	15
gravel	15	19
blue clay	19	73
gravel	73	76
blue clay	76	158
coarse sand	158	171
sandy clay	171	175

(Use separate sheet if necessary)

10. DATE COMPLETED 11/18/24

11. WAS WELL PLUGGED OR ABANDONED? ☑ Yes ☐ No

If so, how bentonite

12. REMARKS: Old well was under new running track. Sealed and moved

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Falk Drilling — 126

Driller's or Firm's Name — License No

Hanginson

Address

Mark Falk — 11/20/24

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY