



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

FEB 07 2025

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

ND DEPT. OF WATER RESOURCES

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name Rory Fastveet				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 4320 169th Ave SW Beach ND 58261				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 71			
		County Golden Valley		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4	GPM Flow Through Inch Pipe		
		NE	NE	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
Township 140N		Range 105E		Section 22		WELL TEST DATA	
PROPOSED USE 14010522AA				☒ Pump ☐ Bailer ☒ Other Air			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				95 2 12			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches 8"		Depth In Feet 116		yellow sand		0 14	
Casing:				yellow clay		14 16	
☒ Steel ☐ Plastic ☐ Concrete ☐ Other	☐ Threaded ☐ Welded ☐ If Other, Specify _____			gray clay		16 32	
Pipe Weight	Diameter	From	To	coal		32 33	
28 lb/ft	8" inches	+2 feet	20 feet	gray shale		33 77	
SDR17	4.5" inches	0 feet	96 feet	gray sand		77 111	
				coal		111 113	
				gray shale		113 116	
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval continuous		From In Feet 96	To In Feet 116				
Was Casing Left Open End? ☒ Yes ☐ No							
Material PVC		Diameter In Inches 4.5		Use Separate Sheet If Necessary			
Slot Size .025	Set From In Feet 96	To In Feet 116		DATE COMPLETED 7-30-24			
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☒ Yes ☐ No				If So, How			
If So, What Material 8/12 silica sand		Depth In Feet 75		REMARKS			
Type Of Well ☐ Straight Screen ☒ Gravel Packed							
Depth Grouted 75	From 0	To 75					
Grouting Material bentonite	Cement	Other					
If Other, Explain:							
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION			
12" Above Grade X		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
If Other, Specify				Driller's Or Firm's Name H&H Drilling		Certificate Number 162	
				Address 109 west river road lane Glendive, Mt 59330			
				Signed By Mike Haggerty		Date 8-27-24	