



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

FEB 07 2025

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

ND DEPT. OF WATER RESOURCES

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name Rick Bostyan				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 4901 HWY 16 Golva, ND 58632				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 17			
		County Golden Valley		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4			
		NW		NE			
Township 137N		Range 106E		Section 15		GPM Flow Through Inch Pipe	
PROPOSED USE 13710615AB				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				WELL TEST DATA			
METHOD DRILLED				☐ Pump ☐ Bailer ☒ Other Air			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Pumping Level Below Land Surface			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				40 2 40			
Bacteriological Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
If So, To What Laboratory Was It Sent?				Feet After Hrs. Pumping GPM			
WELL CONSTRUCTION				WELL LOG			
Diameter Of Hole In Inches 8"		Depth In Feet 57		Formation		Depth (ft.) From To	
Casing: ☒ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				yellow sand		0 7	
Pipe Weight lb/ft 28		Diameter inches 8"		From feet +2		To feet 38	
SDR 17		4.5		0		37	
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☐ No							
Screen Or Perforation Interval .025		From In Feet 37		To In Feet			
Was Casing Left Open End? ☒ Yes ☐ No							
Material PVC		Diameter In Inches 4.5"		Use Separate Sheet If Necessary			
Slot Size .025		Set From In Feet 37		To In Feet 57			
Was Packer Or Seal Used? ☒ Yes ☐ No				DATE COMPLETED 8-2-24			
If So, What Material 8/12 silica sand		Depth In Feet 30-57		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted 40		From 0		To 40			
Grouting Material bentonite		Cement		Other			
If Other, Explain:							
Well Head Completion: Pitless Unit pitless				DRILLER'S CERTIFICATION			
12" Above Grade yes		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
If Other, Specify				Driller's Or Firm's Name H&H Drilling			
				Certificate Number 162			
				Address 109 west river road lane Glendive, Mt 59330			
				Signed By Mike Haggerty			
				Date 8-27-24			