




WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

FEB 07 2025

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

ND DEPT. OF WATER RESOURCES

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name Alex Maus				Was Well Disinfected Upon Completion? ☐ Yes ☒ No			
Address 2990 Co Rd 11 Sentinel Butte ND 58654				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 87			
		County Golden Valley		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4	Inch Pipe		
		NW	NW	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
Township 141N		Range 104E		Section 26		WELL TEST DATA	
PROPOSED USE 14110426BB				☐ Pump ☐ Bailer ☒ Other			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				230 4 20			
WATER QUALITY Was a water sample collected for:				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
If So, To What Laboratory Was It Sent?				WELL LOG			
WELL CONSTRUCTION				Formation Depth (ft.)			
Diameter Of Hole In Inches 8"		Depth In Feet 340		From To			
Casing: ☒ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____							
Pipe Weight	Diameter	From	To				
lb/ft	8" inches	+2 feet	20 feet				
lb/ft	4.5" inches	0 feet	300 feet				
SDR17							
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval Continuous		From In Feet 300	To In Feet 340				
Was Casing Left Open End? ☒ Yes ☐ No							
Material PVC		Diameter In Inches 4.5"		Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet					
.025	300	340					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☒ Yes ☐ No				DATE COMPLETED 8/5/24			
If So, What Material Pea Gravel		Depth In Feet 140-340		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted 140		From 0	To 140				
Grouting Material Bentonite		Cement	Other				
If Other, Explain:							
Well Head Completion: Pitless Unit 2' above ground				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
If Other, Specify				Driller's Or Firm's Name H&H Drilling		Certificate Number 162	
				Address 109 west river rd lane glendive mt 59330			
				Signed By Mike Haggerty		Date 8/9/24	