STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

RECEIVED
FEB 25 2025
ND DEPT. OF WATER RESOURCES

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER
Name MAGNUS - JR LEWING
Address WILLISTON

2. WELL LOCATION
Sketch map location must agree with written location.

NORTH
1 MILE
X
Sec. (1 mile)

15610311CBC

County WILLIAMS
SW 1/4 NW 1/4 SW 1/4 Sec. 11 Twp. 156 N. Rg. 103 W.

3. PROPOSED USE
☐ Domestic ☒ Stock ☐ Geothermal ☒ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger
If other, specify

5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☒ No
If so, to what laboratory was it sent?

6. WELL CONSTRUCTION
Diameter of hole 13 3/4 inches. Depth 52 feet.
Casing: ☐ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other
If other, specify

Pipe Weight:	Diameter:	From:	To:
STEEL lb/ft	9 5/8 inches	-2 feet	52 feet
SDR17 lb/ft	5 inches	-3 feet	60 feet
lb/ft	inches	feet	feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from N/A ft. to feet
Was casing left open end? ☐ Yes ☒ No
Was a well screen installed? ☒ Yes ☐ No
Material STAINLESS Diameter 5 inches
Slot Size 20 set from 60 feet to 70 feet
Slot Size set from feet to feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material N/A Depth ft.
Type of well: Straight screen ☐ Gravel packed ☒ ~~8/16~~
Depth grouted: From 0 To 50
Grouting Material: Cement Other X
If other, explain: 3/8 BENTONITE CHIPS
Well head completion: Pitless unit NO
12" above grade YES Other
If other, specify
Was pump installed? ☒ Yes ☐ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL
Static water level 2 feet ~~below~~ ABOVE surface
If flowing: closed-in pressure psi
GPM flow through inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify

8. WELL TEST DATA
☒ Pump ☐ Bailer ☐ Other
Pumping level below land surface:
8 ft. after 48 hrs. pumping 114 gpm
ft. after hrs. pumping gpm
ft. after hrs. pumping gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
TOP SOIL	0	1
CLAY - YLB - SANDY	1	6
GRAVEL - SM/MED - RUSTY	6	12
CLAY - YLB - SANDY	12	43
CLAY - GRAY - FIRM	43	59
LIGNITE - LOOSE	59	67
CLAY - GRAY - FIRM	67	70

(Use separate sheet if necessary)

10. DATE COMPLETED 11/02/24

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☒ No
If so, how

12. REMARKS:

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.
SOLID WATER WELL DRILLING
Driller's or Firm's Name PARK RICE Certificate No. 207
Address
Park G. Rice 02/16/25
Signed by Date

WHITE-BOARD'S COPY YELLOW-DRILLER'S COPY PINK-CUSTOMER'S COPY