



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

MAR 10 2025

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504 ND DEPT. OF WATER RESOURCES
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Penny Cirks</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>5515 174th Ave SE Christine, ND 58015</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>16</u>			
		County <u>Richland</u>		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4 <u>NW</u>		1/4 <u>NW</u>		1/4 <u>NE</u>	
		Township <u>135N</u>		Range <u>49W</u>		Section <u>2</u>	
PROPOSED USE <u>13504902ARB</u>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☐ Pump ☐ Bailer ☒ Other <u>Air</u>			
☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After <u>23</u> Hrs. Pumping <u>4</u> GPM <u>35</u>			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After Hrs. Pumping GPM			
☐ Bored ☐ Auger ☐ If Other, Specify				Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☐ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☐ No				From To			
If So, To What Laboratory Was It Sent?				<u>Topsoil</u> <u>0</u> <u>2</u>			
WELL CONSTRUCTION				<u>Yellow Clay</u> <u>2</u> <u>32</u>			
Diameter Of Hole In Inches <u>8 7/8</u>		Depth In Feet <u>103</u>		<u>Blue Clay</u> <u>32</u> <u>64</u>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other				<u>Blue Clay w/ gravel strips</u> <u>64</u> <u>80</u>			
☐ Threaded ☐ Welded ☐ If Other, Specify				<u>Blue Clay</u> <u>80</u> <u>88</u>			
Pipe Weight	Diameter	From	To	<u>Blue Clay w/ gravel strips</u> <u>88</u> <u>95</u>			
lb/ft <u>SPR-21</u>	inches <u>4</u>	feet <u>0</u>	feet <u>93</u>	<u>Coarse gray sand</u> <u>95</u> <u>100</u>			
lb/ft	inches	feet	feet	<u>Medium gray gravel</u> <u>100</u> <u>103</u>			
lb/ft	inches	feet	feet	<u>Blue Clay</u> <u>103</u> <u>108</u>			
Was A Well Screen Installed? ☒ Yes ☐ No				Use Separate Sheet If Necessary			
Was Perforated Pipe Used? ☐ Yes ☒ No				DATE COMPLETED <u>11-12-24</u>			
Screen Or Perforation Interval		From In Feet	To In Feet	WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Casing Left Open End? ☐ Yes ☒ No				If So, How			
Material <u>PVC</u>		Diameter In Inches <u>4</u>		REMARKS			
Slot Size <u>0.040</u>	Set From In Feet <u>93</u>	To In Feet <u>103</u>					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No							
If So, What Material		Depth In Feet					
Type Of Well ☐ Straight Screen ☒ Gravel Packed							
Depth Grouted		From <u>0</u>	To <u>88</u>				
Grouting Material		Cement	Other <u>Grout-Well</u>				
If Other, Explain: <u>Tremie line pressure grouted from bottom to top</u>				DRILLER'S CERTIFICATION			
Well Head Completion: Pitless Unit <u>yes</u>				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
12" Above Grade <u>yes</u>		Other (Specify)		Driller's Or Firm's Name <u>Wieber Drilling LLC</u>		Certificate Number <u>211</u>	
It Other, Specify				Address <u>214 Wiley Ave S Lidgerwood, ND 58053</u>			
				Signed By <u>Derek Wieber</u>		Date <u>12-30-24</u>	