



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

Received by email
October 5, 2025

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☐ Yes ☒ No	
Name Klint Sickler		Was Well Disinfected Upon Completion? ☒ Yes ☐ No	
Address 2171 102 Ave SW, Gladstone, ND 58630		WATER LEVEL	
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (In Feet) Below Surface 165	
	County Dunn	GPS	
	1/4 NE	1/4 NE	1/4 SW
	Township 142	Range 95	Section 24
PROPOSED USE 14209524CBA		If Flowing, Closed-In Pressure In PSI	
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		GPM Flow Through Inch Pipe	
METHOD DRILLED		Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Borad ☐ Auger ☐ If Other, Specify	
WATER QUALITY Was a water sample collected for		WELL TEST DATA	
Chemical Analysis? ☒ Yes ☐ No		☐ Pump ☐ Bailer ☒ Other air compressor	
Bacteriological Analysis? ☒ Yes ☐ No		Pumping Level Below Land Surface	
If So, To What Laboratory Was It Sent? by owner		280 Feet After 1 Hrs. Pumping 15 GPM	
WELL CONSTRUCTION		240 Feet After Hrs. Pumping 11 GPM	
Diameter Of Hole In Inches 9		220 Feet After Hrs. Pumping 7 GPM	
Depth In Feet 294		WELL LOG	
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify		Formation	
Pipe Weight		Depth (ft.)	
Diameter		From To	
From		topsoil 0 1	
To		yellow/brown sandy clay 1 25	
lb/ft		gray shale 25 135	
5 inches		coal 135 140	
0 feet		gray shale 140 225	
214 feet		fine to medium blue sand 225 288	
234 feet		coal 288 294	
feet		gray shale 294 305	
Was A Well Screen Installed? ☒ Yes ☐ No			
Was Perforated Pipe Used? ☒ Yes ☐ No			
Screen Or Perforation Interval			
From In Feet 234 To In Feet 294			
Was Casing Left Open End? ☐ Yes ☒ No			
Material			
PVC SLOTTED			
Diameter In Inches 5			
Slot Size		Use Separate Sheet If Necessary	
Set From In Feet 234 To In Feet 294			
Slot Size			
Set From In Feet To In Feet			
Was Packer Or Seal Used? ☐ Yes ☒ No		DATE COMPLETED September 30, 2025	
If So, What Material		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No	
Depth In Feet		If So, How	
Type Of Well ☐ Straight Screen ☒ Gravel Packed		REMARKS	
Depth Grouted			
From 0-30 & 180 To 200			
Grouting Material			
bentonite chips			
If Other, Explain:			
Well Head Completion: Please Unit		DRILLER'S CERTIFICATION	
12" Above Grade		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.	
xx		Driller's Or Firm's Name	
If Other, Specify		Dennis Water Well Drilling, Inc.	
		Certificate Number 61	
		Address	
		10240 Highway 10, Gladstone, ND 58630-9530	
		Signed By	
		James E. Dennis	
		Date	
		October 3, 2025	