



WELL DRILLER'S REPORT
NORTH DAKOTA DEPARTMENT OF WATER RESOURCES
WATER APPROPRIATION
SFN 60273 (7/2025)

RECEIVED

DEC 10 2025

ND DEPT. OF WATER RESOURCES

Department of Water Resources • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the Department of Water Resources within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☒ Yes ☐ No	
Name <u>Tri City JDA</u>		Was Well Disinfected Upon Completion? ☒ Yes ☐ No	
Address <u>Elgin ND</u>		WATER LEVEL	
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (In Feet) Below Surface <u>36</u>	
	County <u>Grant</u>	GPS <u>✓</u>	
	1/4 <u>46</u>	1/4 <u>59305</u>	1/4 <u>101.82448</u>
	Township <u>136</u>	Range <u>89</u>	Section <u>14</u>
PROPOSED USE <u>3608914DAC</u>		WELL TEST DATA	
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial		☐ Pump ☐ Bailer ☒ Other <u>Air</u>	
☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		Pumping Level Below Land Surface	
METHOD DRILLED		Feet After <u>60</u> Hrs. Pumping <u>1</u> GPM <u>10</u>	
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary		Feet After <u>75</u> Hrs. Pumping <u>1.5</u> GPM <u>15+</u>	
☐ Bored ☐ Auger ☐ If Other, Specify _____		Feet After _____ Hrs. Pumping _____ GPM _____	
WATER QUALITY Was a water sample collected for:		WELL LOG	
Chemical Analysis? ☐ Yes ☒ No		Formation	
Bacteriological Analysis? ☐ Yes ☒ No		Depth (ft.)	
If So, To What Laboratory Was It Sent?		From To	
WELL CONSTRUCTION		<u>Brown Sand</u> <u>0</u> <u>8</u>	
Diameter Of Hole In Inches <u>7 1/2</u> Depth In Feet <u>100</u>		<u>Sandstone</u> <u>8</u> <u>9</u>	
Casing:		<u>Brown Sand</u> <u>9</u> <u>63</u>	
☐ Steel ☒ Plastic ☐ Concrete ☐ Other		<u>Gray Sand</u> <u>63</u> <u>100</u>	
☐ Threaded ☐ Welded ☐ If Other, Specify _____			
Pipe Weight	Diameter	From	To
<u>1.92</u> lb/ft	<u>4</u> inches	<u>+2</u> feet	<u>100</u> feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet
Was A Well Screen Installed? ☐ Yes ☒ No			
Was Perforated Pipe Used? ☒ Yes ☐ No			
Screen Or Perforation Interval	From In Feet	To In Feet	
	<u>80</u>	<u>100</u>	
Was Casing Left Open End? ☐ Yes ☒ No			
Material	Diameter In Inches		
Slot Size	Set From In Feet	To In Feet	
Slot Size	Set From In Feet	To In Feet	
Was Packer Or Seal Used? ☐ Yes ☒ No		DATE COMPLETED <u>11-24-25</u>	
If So, What Material	Depth In Feet	WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☐ No	
Type Of Well ☐ Straight Screen ☒ Gravel Packed <u>Silica</u>		If So, How	
Depth Grouted	From <u>70</u> To <u>8</u>	REMARKS	
Grouting Material	Cement <u>Enviroplug</u> Other		
If Other, Explain:			
Well Head Completion: Pitless Unit <u>Y</u>		DRILLER'S CERTIFICATION	
12" Above Grade <u>Y</u>	Other (Specify)	This well was drilled under my jurisdiction and this report is true to the best of my knowledge.	
If Other, Specify		Driller's Or Firm's Name <u>Opp Well Drilling</u>	License Number <u>76</u>
		Address <u>Elgin, ND</u>	
		Signature <u>Mark Butcher</u>	Date <u>12-5-25</u>