



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

DEC 12 2025

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <i>Terry Rucksted</i>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <i>3121 Valley Dr. Bismarck ND</i>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>266</i>			
		County <i>Belling</i>		GPS <i>Shop Well</i>		If Flowing, Closed-In Pressure In PSI	
		1/4 <i>SW</i>		1/4 <i>SW</i>		GPM Flow Through Inch Pipe	
		Township <i>139</i>		Range <i>102</i>		Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____	
		Section <i>27</i>					
PROPOSED USE <i>13910227CC</i>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <i>320</i> Hrs. Pumping <i>5</i> GPM <i>15</i>			
WATER QUALITY Was a water sample collected for				Feet After _____ Hrs. Pumping _____ GPM _____			
Chemical Analysis? ☐ Yes ☒ No				Feet After _____ Hrs. Pumping _____ GPM _____			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.) From To			
WELL CONSTRUCTION				<i>Sand Brown</i> <i>0</i> <i>29</i>			
Diameter Of Hole In Inches <i>9 7/8</i>		Depth In Feet <i>340</i>		<i>Sand Gray</i> <i>29</i> <i>38</i>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				<i>Clay Gray</i> <i>38</i> <i>125</i>			
Pipe Weight	Diameter	From	To	<i>Coal</i> <i>125</i> <i>140</i>			
lb/ft	inches	feet	feet	<i>Clay Gray</i> <i>140</i> <i>176</i>			
<i>SDR 21</i>	<i>5</i>	<i>41</i>	<i>272</i>	<i>Coal</i> <i>176</i> <i>184</i>			
lb/ft	inches	feet	feet	<i>Clay Gray</i> <i>184</i> <i>199</i>			
<i>SDR 21</i>	<i>5</i>	<i>332</i>	<i>340</i>	<i>Sand Gray Fine</i> <i>199</i> <i>239</i>			
lb/ft	inches	feet	feet	<i>Clay Gray</i> <i>239</i> <i>250</i>			
Was A Well Screen Installed? ☒ Yes ☐ No				<i>Sand Gray</i> <i>250</i> <i>257</i>			
Was Perforated Pipe Used? ☐ Yes ☒ No				<i>Clay Gray</i> <i>257</i> <i>273</i>			
Screen Or Perforation Interval	From In Feet	To In Feet		<i>Sand Gray Medium</i> <i>273</i> <i>332</i>			
Was Casing Left Open End? ☒ Yes ☐ No				<i>Clay Gray</i> <i>332</i> <i>340</i>			
Material <i>PVC SDR 17</i>	Diameter In Inches <i>5</i>			Use Separate Sheet If Necessary			
Slot Size <i>16</i>	Set From In Feet <i>272</i>	To In Feet <i>332</i>		DATE COMPLETED <i>8-21-25</i>			
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☒ Yes ☐ No				If So, How			
If So, What Material <i> Bentonite Chips</i>	Depth In Feet <i>243</i>			REMARKS			
Type Of Well ☐ Straight Screen ☒ Gravel Packed							
Depth Grouted	From	To					
	<i>0</i>	<i>30</i>					
Grouting Material	Cement	Other <i>Bentonite Chips</i>					
If Other, Explain:							
Well Head Completion: Pitless Unit <i>Yes</i>				DRILLER'S CERTIFICATION			
12" Above Grade <i>Yes</i>	Other (Specify)			This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <i>Gregory Water & Energy Inc.</i> Certificate Number <i>154</i>			
				Address <i>3484 114th Ave SW - Dickinson ND.</i>			
				Signed By <i>Terry Rucksted</i> Date <i>8-30-25</i>			