



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

DEC 11 2025

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Delvin Dutart 58642</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>10271 15th St SW Manning ND</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>85</u>			
		County <u>Dunn</u>		GPS <u>see Remarks</u>		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4			
		Township	Range	Section			
PROPOSED USE <u>14309513BDA</u>				GPM Flow Through Inch Pipe			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
METHOD DRILLED				WELL TEST DATA			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				☐ Pump ☐ Bailer ☒ Other			
WATER QUALITY Was a water sample collected for				Pumping Level Below Land Surface			
Chemical Analysis? ☐ Yes ☒ No				Feet After <u>220</u> Hrs. Pumping <u>2</u> GPM <u>10</u>			
Bacteriological Analysis? ☐ Yes ☒ No				Feet After _____ Hrs. Pumping _____ GPM _____			
If So, To What Laboratory Was It Sent?				Feet After _____ Hrs. Pumping _____ GPM _____			
WELL CONSTRUCTION				WELL LOG			
Diameter Of Hole In Inches <u>7.5</u>		Depth In Feet <u>300</u>		Formation		Depth (ft.)	
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____						From	To
Pipe Weight	Diameter	From	To	Brown Clay		0	40
lb/ft	inches	feet	feet	Grey clay		40	55
<u>200</u>	<u>4</u>	<u>255</u>	<u>+2</u>	Coal		55	56
lb/ft	inches	feet	feet	Grey clay		56	85
lb/ft	inches	feet	feet	Coal		85	86
				Grey clay		86	105
				Coal w/ partings		105	109
				Grey clay		109	155
				Fine sand w/ silt layers		155	165
				Grey clay		165	206
				Fine sand w/ silt layers		206	236
				Grey clay		236	250
				Fine sand very fine		250	286
				Coal		286	296
				Grey clay		296	300
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval		From In Feet	To In Feet				
Was Casing Left Open End? ☐ Yes ☒ No							
Material		Diameter In Inches					
Slot Size	Set From In Feet	To In Feet		Use Separate Sheet If Necessary			
<u>25</u>	<u>255</u>	<u>300</u>					
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED <u>6-20-2025</u>			
				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How			
If So, What Material		Depth In Feet		REMARKS			
				2184 Elev Solar Pump to be 41° 12' 28.13" N Installed later 102° 39' 44.56" W			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				DRILLER'S CERTIFICATION			
Depth Grouted		From	To	This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Grouting Material		Cement	Other	Driller's Or Firm's Name <u>Math Drilling</u> Certificate Number <u>106</u>			
			<u>Benseal</u>	Address <u>Benson ND 58523</u>			
If Other, Explain:				Signed By <u>John Mdel</u> Date <u>7-12-2025</u>			
Well Head Completion: Pitless Unit							
12" Above Grade <u>X</u>		Other (Specify)					
It Other, Specify							