



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

DEC 11 2025

ND DEPT OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No <i>Solar</i>			
Name <i>Kevin Lee</i>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <i>61915th NW Bismarck ND 58503</i>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>90</i>			
		County <i>Mercer</i>		GPS <i>Remark</i>		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4			
		Township		Range	Section		
PROPOSED USE <i>14403915CDD</i>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <i>160</i> Hrs. Pumping <i>2</i> GPM <i>7</i>			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches <i>7 7/8</i>		Depth In Feet <i>195</i>		<i>Brown Clay</i>		<i>26</i>	
Casing:				<i>COAL</i>		<i>26 27</i>	
☐ Steel ☒ Plastic ☐ Concrete ☐ Other	☐ Threaded ☐ Welded ☐ If Other, Specify _____			<i>Grey Clay</i>		<i>27 38</i>	
Pipe Weight	Diameter	From	To	<i>COAL</i>		<i>38 39</i>	
<i>200</i> lb/ft	<i>4</i> inches	<i>170</i> feet	<i>+2</i> feet	<i>Grey Clay</i>		<i>39 64</i>	
				<i>COAL</i>		<i>64 67</i>	
				<i>Grey Clay</i>		<i>67 75</i>	
				<i>COAL</i>		<i>75 76</i>	
				<i>Grey Clay</i>		<i>76 96</i>	
				<i>Silty Sand</i>		<i>96 104</i>	
				<i>Grey Clay</i>		<i>134 140</i>	
				<i>Silty Sand + Clay</i>		<i>140 173</i>	
				<i>COAL</i>		<i>173 177</i>	
				<i>Grey Clay</i>		<i>177 186</i>	
				<i>COAL</i>		<i>186 194</i>	
				<i>Grey Clay</i>		<i>194 200</i>	
Was A Well Screen Installed? ☒ Yes ☐ No				Use Separate Sheet If Necessary			
Was Perforated Pipe Used? ☐ Yes ☐ No				DATE COMPLETED <i>10-15-25</i>			
Screen Or Perforation Interval		From In Feet <i>170</i>	To In Feet <i>195</i>	WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Casing Left Open End? ☐ Yes ☒ No				If So, How			
Material <i>PVC</i>		Diameter In Inches <i>4</i>		REMARKS			
Slot Size <i>.25</i>	Set From In Feet <i>170</i>	To In Feet <i>195</i>		<i>47° 17' 10.98" N</i>			
Slot Size	Set From In Feet	To In Feet		<i>101° 56' 48.54" W</i>			
Was Packer Or Seal Used? ☐ Yes ☒ No				<i>Elev 1908'</i>			
If So, What Material		Depth In Feet		DRILLER'S CERTIFICATION			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Depth Grouted	From <i>157</i>	To <i>0</i>		Driller's Or Firm's Name <i>MOH2 Drilling</i> Certificate Number <i>105</i>			
Grouting Material	Cement	Other <i>Ben Seal</i>		Address <i>Bismarck ND</i>			
If Other, Explain:				Signed By <i>John Mohr</i> Date <i>05.09.2025</i>			
Well Head Completion: Pitless Unit							
12" Above Grade <i>A</i>		Other (Specify)					
If Other, Specify							