



DEC - 1 2025

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name <u>DAVIS KINN 58716</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>2457 18th St NW Benedict ND</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>26</u>			
		County <u>Mcken</u>		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4 <u>NW</u>	1/4 <u>NW</u>	1/4 <u>SE</u>	GPM Flow Through Inch Pipe		
		Township <u>149</u>	Range <u>82</u>	Section <u>11</u>	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____		
PROPOSED USE <u>14908211DBB</u>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other <u>Air</u>			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <u>70</u> Hrs. Pumping <u>2</u> GPM <u>50</u>			
WATER QUALITY Was a water sample collected for				Feet After _____ Hrs. Pumping _____ GPM _____			
Chemical Analysis? ☐ Yes ☒ No				WELL LOG			
Bacteriological Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
If So, To What Laboratory Was It Sent?				From To			
WELL CONSTRUCTION				<u>Gravel</u> <u>0</u> <u>1</u>			
Diameter Of Hole In Inches <u>7 1/8</u> Depth In Feet <u>72</u>				<u>yellow clay</u> <u>1</u> <u>5</u>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				<u>sand & gravel</u> <u>5</u> <u>18</u>			
Pipe Weight	Diameter	From	To	<u>Gravel</u> <u>18</u> <u>21</u>			
lb/ft <u>Sch 40</u>	inches <u>4 1/2</u>	feet <u>0</u>	feet <u>72</u>	<u>sand & Gravel</u> <u>21</u> <u>27</u>			
lb/ft	inches	feet	feet	<u>sand & gravel washed</u> <u>27</u> <u>74</u>			
lb/ft	inches	feet	feet	<u>Gravel</u> <u>74</u> <u>80</u>			
Was A Well Screen Installed? ☐ Yes ☐ No				Use Separate Sheet If Necessary			
Was Perforated Pipe Used? ☒ Yes ☐ No				DATE COMPLETED <u>7-27-2025</u>			
Screen Or Perforation Interval	From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
<u>10</u>	<u>62</u>	<u>72</u>		If So, How			
Was Casing Left Open End? ☐ Yes ☒ No				REMARKS			
Material <u>P.O.C</u>	Diameter In Inches <u>4 1/2</u>						
Slot Size <u>.020</u>	Set From In Feet <u>62</u>	To In Feet <u>72</u>					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No				DRILLER'S CERTIFICATION			
If So, What Material		Depth In Feet		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				Driller's Or Firm's Name <u>Stemco Oil Drilling LLC</u> Certificate Number <u>52</u>			
Depth Grouted	From <u>top</u>	To <u>27</u>		Address <u>2919 17th St NW Coleharbor, ND 58531</u>			
Grouting Material <u>Bentonite clay chips</u>	Cement	Other		Signed By <u>[Signature]</u> Date <u>7-27-2025</u>			
If Other, Explain:							
Well Head Completion: Pitless Unit							
12" Above Grade <u>X</u>	Other (Specify)						
If Other, Specify							