



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

DEC 31 2025

NO DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No					
Name <u>Roger Baker</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No					
Address <u>11601 HWY 1804 Ray ND 58849</u>				WATER LEVEL					
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>70'</u>					
		County <u>Williams</u>		GPS		If Flowing, Closed-In Pressure In PSI			
		1/4	1/4	1/4					
		Township <u>154N</u>	Range <u>96W</u>	Section <u>10</u>					
PROPOSED USE <u>IS409610 DCD</u>				WELL TEST DATA					
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other					
METHOD DRILLED				Pumping Level Below Land Surface					
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <u>74'</u> Hrs. Pumping <u>3</u> GPM <u>30</u>					
WATER QUALITY Was a water sample collected for				Feet After _____ Hrs. Pumping _____ GPM _____					
Chemical Analysis? ☒ Yes ☐ No				Feet After _____ Hrs. Pumping _____ GPM _____					
Bacteriological Analysis? ☒ Yes ☐ No				WELL LOG					
If So, To What Laboratory Was It Sent? <u>Astro-chem</u>				Formation Depth (ft.)					
WELL CONSTRUCTION				From To					
Diameter Of Hole In Inches <u>8.75</u>		Depth In Feet <u>225</u>		Fire Brown sand		<u>0</u> <u>23</u>			
Casing:				Fire-Med sand scoria		<u>23</u> <u>38</u>			
☐ Steel ☒ Plastic ☐ Concrete ☐ Other	☐ Threaded ☐ Welded ☐ If Other, Specify _____			Fire Brown sand		<u>38</u> <u>86</u>			
Pipe Weight <u>2.9</u> lb/ft	Diameter <u>5</u> inches	From <u>+2</u> feet	To <u>210</u> feet	Med to coarse sand fire gravel & coal		<u>86</u> <u>141</u>			
<u>cap</u> lb/ft	<u>cap</u> inches	<u>220</u> feet	<u>221</u> feet	Med sand - coarse gravel		<u>141</u> <u>184</u>			
<u>cap</u> lb/ft	<u>cap</u> inches	<u>cap</u> feet	<u>cap</u> feet	Mostly coal + Med sand small gravel		<u>184</u> <u>199</u>			
Was A Well Screen Installed? ☒ Yes ☐ No				Med to very large gravel				<u>199</u> <u>221</u>	
Was Perforated Pipe Used? ☐ Yes ☒ No				Gray shale				<u>221</u> <u>225</u>	
Screen Or Perforation Interval		From In Feet	To In Feet						
Was Casing Left Open End? ☐ Yes ☐ No									
Material <u>stainless steel</u>		Diameter In Inches <u>5</u>							
Slot Size <u>-020</u>		Set From In Feet <u>210</u>	To In Feet <u>220</u>						
Slot Size _____		Set From In Feet _____	To In Feet _____						
Was Packer Or Seal Used? ☐ Yes ☒ No				Use Separate Sheet If Necessary					
If So, What Material		Depth In Feet		DATE COMPLETED <u>11-15-25</u>					
Type Of Well ☐ Straight Screen ☒ Gravel Packed				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No					
Depth Grouted <u>150</u> From		<u>0</u> To		If So, How					
Grouting Material <u>Cement</u>		<u>Bentonite</u> Other		REMARKS					
If Other, Explain:									
Well Head Completion: Pitless Unit <u>Yes</u>				DRILLER'S CERTIFICATION					
12" Above Grade <u>Yes</u>		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.					
It Other, Specify				Driller's Or Firm's Name <u>STS Drilling</u>		Certificate Number <u>141</u>			
				Address <u>PO Box 11354 Williams ND 58801</u>					
				Signed By <u>[Signature]</u>		Date <u>11-21-25</u>			