



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

JAN 09 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name Dustin Laufer				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 405 13th Ave NW Bismarck, ND 58639				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 108			
		County Adams		GPS 46-3737 -121-2215		If Flowing, Closed-In Pressure In PSI	
		1/4 NE	1/4	1/4	GPM Flow 6-8		
		Township 132		Range 96	Section 14	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify	
PROPOSED USE 13209614A				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify				Feet After 180		Hrs. Pumping 2	
WATER QUALITY Was a water sample collected for				Feet After		Hrs. Pumping	
Chemical Analysis? ☐ Yes ☒ No						GPM	
Bacteriological Analysis? ☐ Yes ☒ No							
If So, To What Laboratory Was It Sent?							
WELL CONSTRUCTION				WELL LOG			
Diameter Of Hole In Inches 12.7		Depth In Feet 195		Formation		Depth (ft.)	
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify						From To	
Pipe Weight	Diameter	From	To	sand		0 17	
lb/ft	inches	feet	feet	clay		17 19	
200	5	0	195	clay		19 32	
				rock		32 33	
				sandy clay		33 36	
				coal		36 39	
				clay		39 68	
				rock		68 69	
				clay		69 74	
				coal		74 77	
				clay		77 89	
				fine sand		89 117	
				rock		117 118	
				clay		118 139	
				fine sand		139 143	
				clay		143 156	
				coal		156 157	
				clay		157 164	
				fine sand		164 194	
				coal		194 195	
Was A Well Screen Installed? ☒ Yes ☐ No				Use Separate Sheet If Necessary			
Was Perforated Pipe Used? ☐ Yes ☐ No				DATE COMPLETED 4-20-2024			
Screen Or Perforation Interval		From In Feet	To In Feet	WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
		163	195	If So, How			
Was Casing Left Open End? ☒ Yes ☐ No				REMARKS			
Material		Diameter In Inches					
PVC		5					
Slot Size	Set From In Feet	To In Feet					
16	165	195					
Slot Size	Set From In Feet	To In Feet		DRILLER'S CERTIFICATION			
				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Was Packer Or Seal Used? ☐ Yes ☒ No				Driller's Or Firm's Name		Certificate Number	
If So, What Material				Knutson Well Drilling		70	
Depth In Feet				Address		Date	
Type Of Well ☐ Straight Screen ☒ Gravel Packed				Bismarck ND		4-20-2024	
Depth Grouted		From	To	Signed By			
		0	160	Robert Knutson			
Grouting Material		Cement	Other	Date			
		X	bentonite	4-20-2024			
If Other, Explain:							
Well Head Completion: Pitless Unit							
12" Above Grade		Other (Specify)					
Yes							
It Other, Specify							