



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED
DEC 15 2025
ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Donn Nelson</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>Fullerton ND</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>51.5</u>			
		County <u>Dickey</u>		GPS <u>46.26569</u> <u>98.28117</u>		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4			
		Township	Range	Section			
PROPOSED USE <u>13206111ABC</u>				GPM Flow Through Inch Pipe			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
METHOD DRILLED				WELL TEST DATA			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				☒ Pump ☐ Bailer ☐ Other			
WATER QUALITY Was a water sample collected for				Pumping Level Below Land Surface			
Chemical Analysis? ☐ Yes ☒ No				Feet After <u>58.6</u>		Hrs. Pumping <u>1</u>	
Bacteriological Analysis? ☐ Yes ☒ No				Feet After		GPM <u>15</u>	
If So, To What Laboratory Was It Sent?				Feet After		GPM	
WELL CONSTRUCTION				WELL LOG			
Diameter Of Hole In Inches <u>9</u>		Depth In Feet <u>120</u>		Formation		Depth (ft.)	
Casing:						From To	
☐ Steel ☒ Plastic ☐ Concrete ☐ Other				<u>Top</u>		<u>0</u> <u>2</u>	
☐ Threaded ☐ Welded ☐ If Other, Specify _____				<u>Fine Brown sand</u>		<u>2</u> <u>5</u>	
Pipe Weight	Diameter	From	To	<u>Brown clay</u>		<u>5</u> <u>20</u>	
lb/ft	inches	feet	feet	<u>Brown sand &</u>		<u>20</u> <u>35</u>	
<u>SDR-21</u>	<u>5</u>	<u>-1 1/2</u>	<u>112</u>	<u>clay layers (rock 29)</u>			
lb/ft	inches	feet	feet	<u>clay</u>		<u>35</u> <u>50</u>	
lb/ft	inches	feet	feet	<u>clay gray</u>		<u>50</u> <u>56</u>	
				<u>Med-coarse gray sand</u>		<u>56</u> <u>58</u>	
				<u>gray clay</u>		<u>58</u> <u>88</u>	
				<u>Med gray sand</u>		<u>88</u> <u>111</u>	
				<u>Drilled tight</u>			
				<u>Med chertey sand</u>		<u>111</u> <u>120</u>	
Was A Well Screen Installed? ☒ Yes ☐ No				Use Separate Sheet If Necessary			
Was Perforated Pipe Used? ☐ Yes ☒ No				DATE COMPLETED <u>11-25-25</u>			
Screen Or Perforation Interval		From In Feet	To In Feet	WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Casing Left Open End? ☐ Yes ☒ No				If So, How			
Material <u>SDR-21</u>		Diameter In Inches <u>5</u>		REMARKS			
Slot Size <u>.50</u>	Set From In Feet <u>112</u>	To In Feet <u>120</u>					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No							
If So, What Material		Depth In Feet		DRILLER'S CERTIFICATION			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Depth Grouted		From <u>8</u>	To <u>20 ft</u>	Driller's Or Firm's Name <u>M & W Drilling</u>		Certificate Number <u>92</u>	
Grouting Material		Cement	Other	Address <u>Oakes ND</u>			
If Other, Explain: <u>Bentonite chips</u>				Signed By <u>Wayne Doty</u>		Date <u>12-07-25</u>	
Well Head Completion: Pitless Unit <u>yes</u>							
12" Above Grade <u>yes</u>		Other (Specify)					
It Other, Specify							