



WELL DRILLER'S REPORT
NORTH DAKOTA DEPARTMENT OF WATER RESOURCES
WATER APPROPRIATION
SFN 60273 (7/2025)

RECEIVED

FEB 23 2026

Department of Water Resources • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the Department of Water Resources within 30 days after completion or abandonment of the well.

NO DEPT. OF WATER RESOURCES

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Paul Johnson</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>2ap ND</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>35</u>			
County <u>Mercer</u>		GPS		If Flowing, Closed-In Pressure In PSI			
1/4 <u>47.4319</u>		1/4 <u>101.953</u>		GPM Flow Through Inch Pipe			
Township <u>144</u>		Range <u>89</u>		Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify			
Section <u>34</u>				WELL TEST DATA			
PROPOSED USE <u>14408934C</u>				☐ Pump ☐ Bailer ☒ Other <u>Air</u>			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				Pumping Level Below Land Surface			
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Feet After <u>50</u> Hrs. Pumping <u>2</u> GPM <u>10</u>			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After Hrs. Pumping GPM			
☐ Bored ☐ Auger ☐ If Other, Specify				Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☒ No				From To			
If So, To What Laboratory Was It Sent?				<u>Brown Clay</u> <u>0</u> <u>11</u>			
WELL CONSTRUCTION				<u>Rock</u> <u>11</u> <u>12</u>			
Diameter Of Hole In Inches <u>7 7/8</u>		Depth In Feet <u>55</u>		<u>Brown Clay</u> <u>12</u> <u>18</u>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other				<u>Gray Clay</u> <u>18</u> <u>41</u>			
☐ Threaded ☐ Welded ☐ If Other, Specify				<u>Coal</u> <u>41</u> <u>44</u>			
Pipe Weight	Diameter	From	To	<u>Clay</u> <u>44</u> <u>45</u>			
<u>1.8</u> lb/ft	<u>4"</u> inches	<u>12</u> feet	<u>55</u> feet	<u>Coal</u> <u>45</u> <u>49</u>			
				<u>Clay</u> <u>49</u> <u>56</u>			
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
	<u>40</u>	<u>50</u>					
Was Casing Left Open End? ☐ Yes ☒ No							
Material		Diameter In Inches		Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No				DATE COMPLETED <u>1-12-26</u>			
If So, What Material		Depth In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☐ No			
				If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed <u>Silica</u>				REMARKS			
Depth Grouted	From	To					
Grouting Material	Cement	Other <u>Enviroplug</u>					
If Other, Explain:							
Well Head Completion: Pitless Unit <u>Y</u>				DRILLER'S CERTIFICATION			
12" Above Grade <u>X</u> Other (Specify)				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>OPP Well Drilling</u> License Number <u>76</u>			
				Address <u>ND</u>			
				Signed By <u>Michael Bottom</u> Date <u>2-4-26</u>			