



WELL DRILLER'S REPORT
NORTH DAKOTA DEPARTMENT OF WATER RESOURCES
WATER APPROPRIATION
SFN 60273 (7/2025)

RECEIVED

MAR 25 2026

ND DEPT. OF WATER RESOURCES

Department of Water Resources • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the Department of Water Resources within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☒ Yes ☐ No	
Name Hamlin Water		Was Well Disinfected Upon Completion? ☒ Yes ☐ No	
Address 5031 141st Ave NW Williston, ND 58801		WATER LEVEL	
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (in Feet) Below Surface 95	
	County Divide	GPS 48.700748 -103.724768	
	1/4 NW	1/4 SW	1/4
	Township 163N	Range 102W	Section 34E
PROPOSED USE 16310234CBB		Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____	
☐ Domestic ☐ Geothermal ☐ Municipal ☒ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		WELL TEST DATA	
METHOD DRILLED		☒ Pump ☐ Sailer ☐ Other	
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____		Pumping Level Below Land Surface	
WATER QUALITY Was a water sample collected for		Feet After Hrs. Pumping GPM	
Chemical Analysis? ☒ Yes ☐ No		100 10 450	
Bacteriological Analysis? ☐ Yes ☐ No		Feet After Hrs. Pumping GPM	
If So, To What Laboratory Was It Sent? Astro-Chem, Williston, ND		Feet After Hrs. Pumping GPM	
WELL CONSTRUCTION		WELL LOG	
Diameter Of Hole In Inches 16"		Formation Depth (ft.)	
Depth In Feet 180		From To	
Casing		Top Soil 0 1	
☒ Steel ☐ Plastic ☐ Concrete ☐ Other ☐ Threaded ☒ Welded ☐ If Other, Specify _____		Sand/Gravel 1 39	
Pipe Weight	Diameter	From	To
40.48	10	+2	142
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet
Was A Well Screen Installed? ☒ Yes ☐ No		Yellow Sandy Till 39 43	
Was Perforated Pipe Used? ☐ Yes ☒ No		Sand/Gravel 43 80	
Screen Or Perforation Interval	From In Feet	To In Feet	Gravel 80 100
Was Casing Left Open End? ☐ Yes ☒ No			Course Sand and Gravel 100 128
Material Stainless Steel Screen	Diameter In Inches 10"		Gray Sand 128 134
Slot Size	Set From In Feet	To In Feet	Sand/Gravel 134 170
70	142	162	Gray till 170 180
Slot Size	Set From In Feet	To In Feet	
Was Packer Or Seal Used? ☐ Yes ☒ No		Use Separate Sheet If Necessary	
If So, What Material	Depth In Feet	DATE COMPLETED 6-1-2025	
Type Of Well ☐ Straight Screen ☒ Gravel Packed		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No	
Depth Grouted Bentonite Chips	From	To	REMARKS
0		50	
Grouting Material	Cement	Other	
If Other, Explain			
Well Head Completion: Pileup Unit Yes		DRILLER'S CERTIFICATION	
12" Above Grade Yes		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.	
If Other, Specify		Driller's Or Firm's Name Agri Industries Inc.	
		License Number 123	
		Address 3105 2nd St West, Williston, ND 58801	
		Signed <i>M. A.</i> Date 17 Jun 2025	

COPY FOR DWR

COPY FOR DRILLER

COPY FOR CUSTOMER