



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

MAR 31 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <i>Scott McDaniel</i>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <i>Englewood ND</i>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>4.3</i>			
				If Flowing, Closed-In Pressure In PSI			
				GPM Flow Through Inch Pipe			
				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
PROPOSED USE <i>13305718DCD</i>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <i>8.4</i> Hrs. Pumping <i>1</i> GPM <i>46</i>			
WATER QUALITY Was a water sample collected for				Feet After _____ Hrs. Pumping _____ GPM _____			
Chemical Analysis? ☐ Yes ☒ No				Feet After _____ Hrs. Pumping _____ GPM _____			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches <i>9"</i> Depth In Feet <i>20 1/2</i>				<i>Top</i> <i>0</i> <i>2</i>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				<i>Brown clay</i> <i>2</i> <i>5</i>			
Pipe Weight Diameter From To				<i>Meal - coarse</i> <i>5</i> <i>12</i>			
<i>50A-21</i> <i>5</i> <i>-1 1/2</i> <i>13 1/2</i>				<i>brown sand</i> <i>12</i> <i>20 1/2</i>			
lb/ft inches feet feet				<i>coarse sand</i>			
lb/ft inches feet feet				<i>& gravel - gray</i>			
lb/ft inches feet feet							
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval From In Feet <i>13 1/2</i> To In Feet <i>20 1/2</i>							
Was Casing Left Open End? ☐ Yes ☒ No							
Material <i>50A-21</i> Diameter In Inches <i>5</i>				Use Separate Sheet If Necessary			
Slot Size <i>.30</i> Set From In Feet <i>13 1/2</i> To In Feet <i>20 1/2</i>				DATE COMPLETED <i>02-20-26</i>			
Slot Size _____ Set From In Feet _____ To In Feet _____				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How			
If So, What Material _____ Depth In Feet _____				REMARKS			
Type Of Well ☐ Straight Screen ☒ Gravel Packed							
Depth Grouted From <i>0</i> To <i>10 ft</i>							
Grouting Material Cement Other							
If Other, Explain: <i>Bentonite Chips</i>							
Well Head Completion: Pitless Unit <i>No</i>				DRILLER'S CERTIFICATION			
12" Above Grade <i>yes</i> Other (Specify) _____				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
If Other, Specify _____				Driller's Or Firm's Name <i>Mt W Drilling</i> Certificate Number <i>92</i>			
				Address <i>Oakes ND</i>			
				Signed By <i>Wayne Doty</i> Date <i>03-17-26</i>			