#3
12x 53 Steel
12x15x70Slot

STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

RECEIVED
MAY 05 2026
ND DEPT. OF WATER RESOURCES

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER
Name Travis Wolf
Address IRRIGATION - 927 34th Ave SE
Chaseley, ND 58423

2. WELL LOCATION
Sketch map location must agree with written location.

GPS _____
EL _____
14407222DBC

NORTH
1 MILE
Sec. (1 mile) _____

County Kidder
SW 1/4 NW 1/4 SE 1/4 Sec. 22 Twp. 144 N. Rg. 72 W.

3. PROPOSED USE
☐ Domestic ☐ Stock ☒ Irrigation ☐ Municipal ☐ Geothermal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger
If other, specify _____

5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☒ No
If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION
Diameter of hole 18 inches. Depth 63 feet.
Casing: ☐ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other
If other, specify _____

Pipe Weight:	Diameter:	From:	To:
____ lb/ft	12 inches	0 feet	38 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☒ No
Was a well screen installed? ☒ Yes ☐ No
Material Stainless Steel Diameter 12 inches
Slot Size 70 set from 38 feet to 53 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☐
Depth grouted: From 0 To 28
Grouting Material: Cement _____ Other _____
If other, explain: _____
Well head completion: Pitless unit _____
12" above grade YES Other _____
If other, specify _____
Was pump installed? ☐ Yes ☒ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL
Static water level 10 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

8. WELL TEST DATA
☐ Pump ☐ Bailer ☐ Other
Pumping level below land surface:
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm
____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation		Depth (ft.) From	Depth (ft.) To
TS	Blk	0	2
Cly	Brn	2	30
Cly / Coal	Gry	30	53
Cly	Gry	53	63

(Use separate sheet if necessary)

10. DATE COMPLETED 4-22-26

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☒ No
If so, how _____

12. REMARKS:
I 3
H20

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Steven M. Traut Wells Inc. 85
Driller's or Firm's Name Certificate No.

Address Steven M. Traut Wells Inc.
754 Cross Country Ln SW
Alexandria, MN 56308

Signed by _____ 4-16-2026
Date

WHITE-BOARD'S COPY YELLOW-DRILLER'S COPY PINK-CUSTOMER'S COPY