#1 well
12x55 Steel
12x15'x70 slot

STATE OF NORTH DAKOTA
BOARD OF WATER WELL CONTRACTORS
900 E. BOULEVARD AVE., DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

RECEIVED
MAY 05 2026
ND DEPT. OF WATER RESOURCES

WELL DRILLER'S REPORT

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER
Name: Travis Wolf
Address: 927 34th Ave. S.E.
Chaseley, ND 58423

2. WELL LOCATION
Sketch map location must agree with written location.

GPS _____
EL _____
14407223BAB

NORTH
1 MILE
Sec. (1 mile) _____

County: Kidder
NW 1/4 NE 1/4 ~~SW~~ 1/4 Sec. 22 Twp 144 N. Rg 72 W.

3. PROPOSED USE
☐ Domestic ☐ Stock ☐ Geothermal ☒ Irrigation ☐ Municipal ☐ Monitoring ☐ Industrial ☐ Test Hole

4. METHOD DRILLED
☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger
If other, specify _____

5. WATER QUALITY
Was a water sample collected for:
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☒ No
If so, to what laboratory was it sent? _____

6. WELL CONSTRUCTION
Diameter of hole 18 inches. Depth 65 feet.
Casing: ☒ Steel ☐ Plastic ☐ Concrete ☐ Threaded ☐ Welded ☐ Other
If other, specify _____

Pipe Weight:	Diameter:	From:	To:
____ lb/ft	12 inches	0 feet	40 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No
Perforated pipe set from _____ ft. to _____ feet
Was casing left open end? ☐ Yes ☐ No
Was a well screen installed? ☒ Yes ☐ No
Material Stainless Steel Diameter 12 inches
Slot Size 70 set from 40 feet to 55 feet
Slot Size _____ set from _____ feet to _____ feet
Was packer or seal used? ☐ Yes ☒ No
If so, what material _____ Depth _____ ft.
Type of well: Straight screen ☐ Gravel packed ☒
Depth grouted: From _____ To 30
Grouting Material: Cement _____ Other Bentonite
If other, explain: _____
Well head completion: Pitless unit _____
12" above grade yes Other _____
If other, specify _____
Was pump installed? ☐ Yes ☒ No
Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL
Static water level 2 feet below surface
If flowing: closed-in pressure _____ psi
GPM flow _____ through ____ inch pipe
Controlled by: ☐ Valve ☐ Reducers ☐ Other
If other, specify _____

8. WELL TEST DATA
☐ Pump ☐ Bailer ☐ Other
Pumping level below land surface:
_____ ft. after _____ hrs. pumping _____ gpm
_____ ft. after _____ hrs. pumping _____ gpm
_____ ft. after _____ hrs. pumping _____ gpm

9. WELL LOG

Formation		Depth (ft.) From	Depth (ft.) To
TS	Blk	0	2
Snd	Brn	2	30
Snd	Gry	30	55
Cly	Gry	55	65

(Use separate sheet if necessary)

10. DATE COMPLETED 4-20-26

11. WAS WELL PLUGGED OR ABANDONED?
☐ Yes ☐ No
If so, how _____

12. REMARKS:
I 2
H 16

Steve Dillon Rick Greg Frank Colo

13. DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Steven M. Traut Wells 85
Driller's or Firm's Name Certificate No.

Address: Steven M. Traut Wells Inc.
754 Cross Country Ln SW
Alexandria, MN 56308

Signed by _____ Date 4-16-2026

WHITE-BOARD'S COPY YELLOW-DRILLER'S COPY PINK-CUSTOMER'S COPY