



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

Received by email
June 3, 2026

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☐ Yes ☒ No	
Name Robbie Ridl Trucking, LLC		Was Well Disinfected Upon Completion? ☒ Yes ☐ No	
Address 11695 39th St SW, Dickinson, ND 58601		WATER LEVEL	
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (In Feet) Below Surface 110	
County Stark		If Flowing, Closed-In Pressure In PSI	
GPS		GPM Flow Through Inch Pipe	
1/4 SW 1/4 SW 1/4 SE		Controlled By ☐ Valve ☐ Reducers ☐ Other	
Township 140		☐ If Other, Specify _____	
Range 98		WELL TEST DATA	
Section 1		☐ Pump ☐ Bailor ☒ Other air compressor	
PROPOSED USE 14009801DCC		Pumping Level Below Land Surface	
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial		Feet After Hrs. Pumping GPM	
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		185 1 15-18	
METHOD DRILLED		Feet After Hrs. Pumping GPM	
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary		Feet After Hrs. Pumping GPM	
☐ Bored ☐ Auger ☐ If Other, Specify _____		Feet After Hrs. Pumping GPM	
WATER QUALITY Was a water sample collected for		WELL LOG	
Chemical Analysis? ☒ Yes ☐ No		Formation Depth (ft.)	
Bacteriological Analysis? ☒ Yes ☐ No		From To	
If So, To What Laboratory Was It Sent? by owner		Topsoil 0 1	
WELL CONSTRUCTION		brown sandy clay 1 19	
Diameter Of Hole In Inches 9		coal 19 20	
Depth In Feet 210		gray shale 20 100	
Casing:		blue clay 100 160	
☐ Steel ☒ Plastic ☐ Concrete ☐ Other		fine blue sand 160 208	
☐ Threaded ☐ Welded ☐ If Other, Specify _____		gray shale 208 212	
Pipe Weight	Diameter	From	To
200 lb/ft	5 inches	0 feet	168 feet
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet
Was A Well Screen Installed? ☒ Yes ☐ No			
Was Perforated Pipe Used? ☒ Yes ☐ No			
Screen Or Perforation Interval	From In Feet	To In Feet	
	168	208	
Was Casing Left Open End? ☐ Yes ☒ No			
Material pvc slotted		Diameter In Inches 5	
Slot Size		Set From In Feet	To In Feet
.025	168	208	
Slot Size	Set From In Feet	To In Feet	
Was Packer Or Seal Used? ☐ Yes ☒ No		DATE COMPLETED May 5, 2026	
If So, What Material		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No	
Depth In Feet		If So, How	
Type Of Well ☐ Straight Screen ☒ Gravel Packed		REMARKS	
Depth Grouted	From	To	2 HP-3 phase motor with controller - Franklin brand 2 HP - 20 gpm water end
Grouting Material	Cement	Other	
		X	
If Other, Explain: bentonite chips		DRILLER'S CERTIFICATION	
Well Head Completion: Please Print		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.	
12" Above Grade xx		Driller's Or Firm's Name Dennis Water Well Drilling, Inc.	
If Other, Specify		Certificate Number 61	
		Address 3645 102G Ave SW, Gladstone, ND 58630	
		Signed By James E. Dennis	
		Date May 15, 2026	