



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED
APR - 1 2026
ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Jacobsen Livestock</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>11327 ND 58001 ND 58765</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>18' 3"</u>			
		County <u>Divide</u>		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4 <u>SW</u>	1/4 <u>SW</u>	1/4 <u>SE</u>	GPM Flow Through Inch Pipe		
		Township <u>164N</u>	Range <u>97W</u>	Section <u>31</u>	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____		
PROPOSED USE <u>16409731CDD</u>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <u>30' 4"</u> Hrs. Pumping <u>2</u> GPM <u>16.6</u>			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☒ Yes ☐ No				WELL LOG			
If So, To What Laboratory Was It Sent? <u>Astoria Chem</u>				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches <u>7.875</u>		Depth In Feet <u>210</u>		<u>Top soil</u> <u>0</u> <u>1</u>			
Casing: ☒ Steel ☒ Plastic ☐ Concrete ☐ Other ☒ Threaded ☐ Welded ☐ If Other, Specify _____				<u>tan fill</u> <u>1</u> <u>19</u>			
Pipe Weight lb/ft <u>28.5</u>	Diameter inches <u>8</u>	From feet <u>11</u>	To feet <u>20</u>	<u>Med sand small gravel</u> <u>19</u> <u>22</u>			
Pipe Weight lb/ft <u>2</u>	Diameter inches <u>4</u>	From feet <u>12</u>	To feet <u>198</u>	<u>Very sandy gray fill</u> <u>22</u> <u>116</u>			
Pipe Weight lb/ft	Diameter inches	From feet	To feet	<u>gray fill</u> <u>116</u> <u>202</u>			
Was A Well Screen Installed? ☒ Yes ☐ No				<u>concentrated sand stone</u> <u>202</u> <u>204</u>			
Was Perforated Pipe Used? ☐ Yes ☒ No				<u>Small to Med Gravel</u> <u>204</u> <u>210</u>			
Screen Or Perforation Interval	From In Feet	To In Feet		<u>Very fine sandstone, clayey</u> <u>210</u> <u>232</u>			
Was Casing Left Open End? ☐ Yes ☒ No				<u>gray clay</u> <u>232</u> <u>260</u>			
Material <u>PVC</u>	Diameter In Inches <u>4</u>			Use Separate Sheet If Necessary			
Slot Size <u>.025</u>	Set From In Feet <u>192</u>	To In Feet <u>210</u>		DATE COMPLETED <u>3-27-26</u>			
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☐ No			
Was Packer Or Seal Used? ☐ Yes ☐ No				If So, How			
If So, What Material		Depth In Feet		REMARKS			
Type Of Well ☐ Straight Screen ☒ Gravel Packed	Depth Grouted From <u>100</u> To <u>0</u>			6PS 48.9821923 - 103.3228386			
Grouting Material Cement	Other <u>Benite</u>			DRILLER'S CERTIFICATION			
If Other, Explain:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
Well Head Completion: Pitless Unit <u>no</u>				Driller's Or Firm's Name <u>Sts Drilling</u> Certificate Number <u>141</u>			
12" Above Grade <u>yes</u>	Other (Specify)			Address <u>PO Box 11354 Williston ND 58803</u>			
If Other, Specify				Signed By <u>[Signature]</u> Date <u>3-30-26</u>			