



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

JUL 31 2026

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND 58105-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name Dan Woodahl				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 1109 67th St. N. Granville, ND 58741				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 12			
		County McHenry		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4	GPM Flow Through Inch Pipe		
		Township 157		Range 79	Section 36	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify	
PROPOSED USE 15707936A				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other Air			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify				Feet After 40 Hrs. Pumping 1 GPM 10			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches 8 3/4		Depth In Feet 70		Surface Sand 0 1			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other				Clay 1 6			
☐ Threaded ☐ Welded ☐ If Other, Specify				Sand 6 19			
Pipe Weight lb/ft 200	Diameter inches 5	From feet +1	To feet 70	Clay 19 26			
				Fine Sand 26 36			
				Clay/Sand Mix 36 40			
				Clean Coarse Sand 40 55			
				Clay 55 70			
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval		From In Feet To In Feet					
Was Casing Left Open End? ☐ Yes ☒ No							
Material Plastic		Diameter In Inches 5					
Slot Size 0.020		Set From In Feet 50 To In Feet 70					
Slot Size		Set From In Feet To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No				DATE COMPLETED 7-16-26			
If So, What Material		Depth In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				If So, How			
Depth Grouted		From 30 To 10		REMARKS			
Grouting Material		Cement Other Enviroplug					
If Other, Explain:							
Well Head Completion: Pitless Unit NO				DRILLER'S CERTIFICATION			
12" Above Grade Yes		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name Certificate Number #102			
				Address Minot, ND			
				Signed By Date 7-25-26			