



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

RECEIVED

JUL 15 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Brandon Barlow</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>1018 Adams Ave, Minot</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>7</u>			
County <u>McHenry</u> GPS 1/4 <u>NW</u> 1/4 <u>NE</u> Township <u>155</u> Range <u>79</u> Section <u>11</u>				If Flowing, Closed-In Pressure In PSI			
				GPM Flow Through Inch Pipe			
PROPOSED USE <u>ISS07911AB</u>				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				WELL TEST DATA			
METHOD DRILLED				☐ Pump ☐ Bailer ☒ Other <u>Air</u>			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Pumping Level Below Land Surface			
WATER QUALITY Was a water sample collected for				Feet After <u>15</u> Hrs. Pumping <u>1/2</u> GPM <u>4-5</u>			
Chemical Analysis? ☐ Yes ☒ No				Feet After _____ Hrs. Pumping _____ GPM _____			
Bacteriological Analysis? ☐ Yes ☒ No				Feet After _____ Hrs. Pumping _____ GPM _____			
If So, To What Laboratory Was It Sent?				WELL LOG			
WELL CONSTRUCTION				Formation <u>Surface Sand</u> Depth (ft.) From <u>0</u> To <u>19</u>			
Diameter Of Hole In Inches <u>8 3/4</u> Depth In Feet <u>19'</u>							
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____							
Pipe Weight	Diameter	From	To				
<u>200</u> lb/ft	<u>5</u> inches	<u>+1</u> feet	<u>19</u> feet				
lb/ft	inches	feet	feet				
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☐ Yes ☒ No							
Was Perforated Pipe Used? ☒ Yes ☐ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
Was Casing Left Open End? ☐ Yes ☒ No							
Material <u>Plastic</u>	Diameter In Inches <u>5</u>			Use Separate Sheet If Necessary			
Slot Size <u>.025</u>	Set From In Feet <u>9</u>	To In Feet <u>19</u>		DATE COMPLETED <u>7-7-26</u>			
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How			
If So, What Material				REMARKS			
Depth In Feet							
Type Of Well ☐ Straight Screen ☒ Gravel Packed							
Depth Grouted	From	To					
Grouting Material	Cement	Other					
If Other, Explain:							
Well Head Completion: Pitless Unit <u>Yes</u>				DRILLER'S CERTIFICATION			
12" Above Grade <u>Yes</u> Other (Specify)				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>Manier Water Well Service</u> Certificate Number <u>102</u>			
				Address <u>Minot, ND</u>			
				Signed By <u>[Signature]</u> Date <u>7-11-26</u>			