




WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

JUN 25 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name <u>JOHNNY SCHUMACHER</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>P.S. 121'</u>			
				If Flowing, Closed-In Pressure In PSI			
				GPM Flow Through Inch Pipe			
				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
County <u>LOGAN</u> GPS <u>ON BOTTOM</u>				WELL TEST DATA			
1/4 1/4 1/4				☒ Pump ☐ Bailer ☐ Other			
Township Range Section				Pumping Level Below Land Surface			
PROPOSED USE <u>1340721388D</u>				Feet After Hrs. Pumping GPM			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				<u>152'</u> <u>OVER 2 HRS</u> <u>10</u>			
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Feet After Hrs. Pumping GPM			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☒ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary							
☐ Bored ☐ Auger ☐ If Other, Specify _____							
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☒ No				From To			
If So, To What Laboratory Was It Sent?				<u>TOPSOIL</u> <u>0</u> <u>2</u>			
WELL CONSTRUCTION				<u>LIGHT BROWN CLAY</u> <u>2</u> <u>39</u>			
Diameter Of Hole In Inches		Depth In Feet		<u>BROWN SANDY CLAY</u> <u>39</u> <u>55</u>			
<u>7 7/8"</u>		<u>154'</u>		<u>GRAY CLAY</u> <u>55</u> <u>62</u>			
Casing:				<u>GRAY SANDY CLAY</u> <u>62</u> <u>73</u>			
☐ Steel ☒ Plastic ☐ Concrete ☐ Other				<u>BROWN / GRAY CLAY MEX</u> <u>73</u> <u>84</u>			
☐ Threaded ☐ Welded ☐ If Other, Specify _____				<u>COAL</u> <u>84</u> <u>91</u>			
Pipe Weight	Diameter	From	To	<u>GRAY SANDY CLAY</u> <u>91</u> <u>102</u>			
<u>SCHD 40</u>	<u>4"</u>	<u>0</u>	<u>134</u>	<u>BLUE BLACK SAND, FINE</u> <u>102</u> <u>114</u>			
lb/ft	inches	feet	feet	<u>GRAY SANDY CLAY</u> <u>114</u> <u>143</u>			
				<u>BLUE BLACK SAND, FINE</u> <u>143</u> <u>154</u>			
Was A Well Screen Installed?	☒ Yes ☐ No						
Was Perforated Pipe Used?	☐ Yes ☒ No						
Screen Or Perforation Interval	From In Feet	To In Feet					
<u>16 SLOT</u>	<u>134</u>	<u>154</u>					
Was Casing Left Open End?	☐ Yes ☒ No						
Material	Diameter In Inches			Use Separate Sheet If Necessary			
<u>PVC SCH 40</u>	<u>4"</u>						
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED <u>6/4/2026</u>			
<u>16</u>	<u>134</u>	<u>154</u>		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Slot Size	Set From In Feet	To In Feet		If So, How			
				REMARKS			
Was Packer Or Seal Used?	☐ Yes ☒ No			<u>GPS - 46.42570° N</u>			
If So, What Material	Depth In Feet			<u>99.68027° W</u>			
Type Of Well	☐ Straight Screen ☒ Gravel Packed <u>40 SLOT</u>			DRILLER'S CERTIFICATION			
Depth Grouted	From	To		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
<u>30</u>	<u>Cement</u>	<u>0</u>		Driller's Or Firm's Name <u>NORTHERN PLAINS PROLOGUE</u> Certificate Number <u>127</u>			
Grouting Material	Cement	Other		Address <u>4007 STATE ST</u>			
If Other, Explain:	<u>MEDIUM CHIPS</u>			Signed By <u>[Signature]</u> Date <u>6/17/2026</u>			
Well Head Completion: Pitless Unit							
12" Above Grade	Other (Specify)						
If Other, Specify							