



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

JUN 25 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No																										
Name Craig Anderson				Was Well Disinfected Upon Completion? ☒ Yes ☐ No																										
Address 1803 Great Deer Drive Arvilla ND 58244				WATER LEVEL																										
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 40																										
<table><tr><td colspan="2">County Grand Forks</td><td colspan="2">GPS</td></tr><tr><td>1/4 NW</td><td>1/4 SE</td><td colspan="2">1/4 SW</td></tr><tr><td>Township 152</td><td>Range 53</td><td colspan="2">Section 31</td></tr></table>				County Grand Forks		GPS		1/4 NW	1/4 SE	1/4 SW		Township 152	Range 53	Section 31		If Flowing, Closed-In Pressure In PSI														
County Grand Forks		GPS																												
1/4 NW	1/4 SE	1/4 SW																												
Township 152	Range 53	Section 31																												
<table><tr><td>GPM Flow</td><td>Through</td><td>Inch Pipe</td></tr></table>				GPM Flow	Through	Inch Pipe	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify																							
GPM Flow	Through	Inch Pipe																												
PROPOSED USE 15205331CDB				WELL TEST DATA																										
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other																										
METHOD DRILLED				Pumping Level Below Land Surface																										
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify				<table><tr><td>Feet After 156</td><td>Hrs. Pumping 2</td><td>GPM 7</td></tr><tr><td>Feet After</td><td>Hrs. Pumping</td><td>GPM</td></tr><tr><td>Feet After</td><td>Hrs. Pumping</td><td>GPM</td></tr></table>				Feet After 156	Hrs. Pumping 2	GPM 7	Feet After	Hrs. Pumping	GPM	Feet After	Hrs. Pumping	GPM														
Feet After 156	Hrs. Pumping 2	GPM 7																												
Feet After	Hrs. Pumping	GPM																												
Feet After	Hrs. Pumping	GPM																												
WATER QUALITY Was a water sample collected for				WELL LOG																										
Chemical Analysis? ☐ Yes ☒ No				<table><tr><td rowspan="2">Formation</td><td colspan="2">Depth (ft.)</td></tr><tr><td>From</td><td>To</td></tr><tr><td>Top Soil</td><td>0</td><td>1</td></tr><tr><td>Brown Clay</td><td>1</td><td>25</td></tr><tr><td>Till</td><td>25</td><td>104</td></tr><tr><td>Sandy Till</td><td>104</td><td>125</td></tr><tr><td>Till</td><td>125</td><td>168</td></tr><tr><td>sand</td><td>168</td><td>178</td></tr></table>				Formation	Depth (ft.)		From	To	Top Soil	0	1	Brown Clay	1	25	Till	25	104	Sandy Till	104	125	Till	125	168	sand	168	178
Formation	Depth (ft.)																													
	From	To																												
Top Soil	0	1																												
Brown Clay	1	25																												
Till	25	104																												
Sandy Till	104	125																												
Till	125	168																												
sand	168	178																												
Bacteriological Analysis? ☐ Yes ☒ No				Use Separate Sheet If Necessary																										
If So, To What Laboratory Was It Sent?				DATE COMPLETED 6-19-2026																										
WELL CONSTRUCTION				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No																										
Diameter Of Hole In Inches				If So, How																										
Depth In Feet 178				REMARKS																										
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify				DRILLER'S CERTIFICATION																										
Pipe Weight				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.																										
Diameter				Driller's Or Firm's Name Lako Drilling, Inc.																										
From				Certificate Number 174																										
To				Address 325 County Road 34 Arthur ND 58006																										
lb/ft Class 200				Signed By Jale Lark																										
lb/ft				Date 6-22-26																										
lb/ft																														
Was A Well Screen Installed? ☒ Yes ☐ No																														
Was Perforated Pipe Used? ☐ Yes ☒ No																														
Screen Or Perforation Interval																														
From In Feet																														
To In Feet																														
Was Casing Left Open End? ☐ Yes ☒ No																														
Material PVC																														
Diameter In Inches 4																														
Slot Size 20																														
Set From In Feet 168																														
To In Feet 178																														
Slot Size																														
Set From In Feet																														
To In Feet																														
Was Packer Or Seal Used? ☐ Yes ☒ No																														
If So, What Material																														
Depth In Feet																														
Type Of Well ☐ Straight Screen ☒ Gravel Packed																														
Depth Grouted																														
From 60																														
To 0																														
Grouting Material																														
Cement																														
Other Bentonite																														
If Other, Explain:																														
Well Head Completion: Pitless Unit																														
12" Above Grade																														
Other (Specify)																														
It Other, Specify																														