



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

JUN 22 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Lennis Larson</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>10051 County Road 8 Binford ND 58416</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>11</u>			
		County <u>Griggs</u>		GPS			
		1/4 <u>SW</u>	1/4 <u>SW</u>	1/4 <u>SE</u>			
		Township <u>147</u>	Range <u>61</u>	Section <u>11</u>			
PROPOSED USE <u>14706111 DCC</u>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After <u>80</u> Hrs. Pumping <u>2</u> GPM <u>100 +</u>			
WATER QUALITY Was a water sample collected for				Feet After _____ Hrs. Pumping _____ GPM _____			
Chemical Analysis? ☐ Yes ☒ No				Feet After _____ Hrs. Pumping _____ GPM _____			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches		Depth In Feet <u>224</u>		Top Soil 0 2			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				Brown Sand 2 9			
Pipe Weight	Diameter	From	To	Brown sandy clay 9 14			
lb/ft <u>Class 200</u>	inches <u>4</u>	feet <u>0</u>	feet <u>204</u>	Gray silty clay 14 86			
lb/ft	inches	feet	feet	Till 86 162			
lb/ft	inches	feet	feet	Soft sandy Till 162 174			
				Till 174 190			
				sand with some clay layers 190 202			
				sand clean 202 219			
				sand with some clay layers 219 226			
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval		From In Feet	To In Feet				
Was Casing Left Open End? ☐ Yes ☒ No							
Material		Diameter In Inches					
Slot Size <u>20</u>	Set From In Feet <u>204</u>	To In Feet <u>224</u>		Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED <u>6-5-2026</u>			
Was Packer Or Seal Used? ☐ Yes ☒ No				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
If So, What Material		Depth In Feet		If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted		From <u>60</u>	To <u>0</u>				
Grouting Material		Cement	Other <u>Bentonite</u>				
If Other, Explain:							
Well Head Completion: Pitless Unit <u>yes</u>				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>Lako Drilling, Inc.</u>		Certificate Number <u>174</u>	
				Address <u>325 County Road 34 Arthur, ND 58006</u>		Signed By <u>Dale Lk</u> Date <u>6-15-2026</u>	