



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

AUG 14 2026

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed?			
Name <i>Steve Burgard</i>				☐ Yes ☒ No			
Address <i>Orin ND</i>				Was Well Disinfected Upon Completion? ☐ Yes ☒ No			
WELL LOCATION				WATER LEVEL			
Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>74.5</i>			
County <i>Glenn</i>				If Flowing, Closed-In Pressure In PSI			
GPS <i>48.0544313</i>				GPM Flow Through <i>Valve</i> Inch Pipe			
Township <i>-100.1801453</i>				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
PROPOSED USE				WELL TEST DATA			
<i>15307421DBC</i>				☐ Pump ☐ Bailer ☐ Other			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After Hrs. Pumping GPM			
WATER QUALITY				Feet After Hrs. Pumping GPM			
Was a water sample collected for							
Chemical Analysis? ☐ Yes ☒ No							
Bacteriological Analysis? ☐ Yes ☒ No							
If So, To What Laboratory Was It Sent?							
WELL CONSTRUCTION				WELL LOG			
Diameter Of Hole In Inches <i>8 3/4</i> Depth In Feet <i>90'</i>				Formation Depth (ft.) From To			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				<i>Sand</i> <i>0</i> <i>30</i>			
Pipe Weight lb/ft	Diameter inches	From feet	To feet	<i>Yellow clay Sand</i> <i>30</i> <i>40</i>			
	<i>5</i>	<i>1</i>	<i>70</i>	<i>Yellow clay Sand</i> <i>40</i> <i>60</i>			
				<i>Sand</i> <i>60</i> <i>80</i>			
				<i>Sand</i> <i>80</i> <i>90</i>			
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval		From In Feet	To In Feet				
Was Casing Left Open End? ☐ Yes ☒ No							
Material <i>Plastic</i>		Diameter In Inches <i>5</i>					
Slot Size <i>25</i>		Set From In Feet <i>70</i>	To In Feet <i>90</i>				
Slot Size		Set From In Feet	To In Feet				
Was Packer Or Seal Used? ☐ Yes ☒ No				Use Separate Sheet If Necessary			
If So, What Material		Depth In Feet		DATE COMPLETED			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
Depth Grouted		From <i>0</i>	To <i>30</i>	If So, How			
Grouting Material		Cement	Other <i>7</i>	REMARKS			
If Other, Explain: <i>Chip Sea Rock</i>				<i>#2</i>			
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <i>Robinson Water Wells</i> Certificate Number <i>302</i>			
				Address <i>Robinson ND</i>			
				Signed By <i>Wayne Kiani</i> Date <i>8-1-26</i>			