



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2020)

Received by email
June 16, 2026

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0860
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER		Was Pump Installed? ☒ Yes ☐ No	
Name Doug Rummel		Was Well Disinfected Upon Completion? ☒ Yes ☐ No	
Address 961 Franklin St, Dickinson, ND 58601		WATER LEVEL	
WELL LOCATION Sketch map location must agree with written location.		Static Water Level (In Feet) Below Surface 77	
County Stark		If Flowing, Closed-In Pressure In PSI	
GPS		GPM Flow Through Inch Pipe	
1/4 SE 1/4 SE 1/4 SE		Controlled By ☐ Valve ☐ Reducers ☐ Other	
Township 138		☐ If Other, Specify _____	
Range 95		WELL TEST DATA	
Section 12		☐ Pump ☐ Bailer ☒ Other air compressor	
PROPOSED USE 13809512000		Pumping Level Below Land Surface	
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial		Feet After Hrs. Pumping GPM	
☐ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole		205 1 1	
METHOD DRILLED		Feet After Hrs. Pumping GPM	
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary		Feet After Hrs. Pumping GPM	
☐ Bored ☐ Auger ☐ If Other, Specify _____			
WATER QUALITY Was a water sample collected for		WELL LOG	
Chemical Analysis? ☒ Yes ☐ No		Formation Depth (ft.)	
Bacteriological Analysis? ☒ Yes ☐ No		From To	
If So, To What Laboratory Was It Sent? by owner		topsoil 0 1	
WELL CONSTRUCTION		brown clay 1 45	
Diameter Of Hole In Inches 9		gray shale 45 106	
Depth In Feet 325		sandy, fine blue sand 106 135	
Casing:		gray shale 135 296	
☐ Steel ☒ Plastic ☐ Concrete ☐ Other		coal 296 299	
☐ Threaded ☐ Welded ☐ If Other, Specify _____		gray shale 299 316	
Pipe Weight	Diameter	From	To
200 lb/ft	5 inches	0 feet	195 feet
290 lb/ft	5 inches	195 feet	295 feet
lb/ft	inches	feet	feet
Was A Well Screen Installed? ☒ Yes ☐ No			
Was Perforated Pipe Used? ☒ Yes ☐ No			
Screen Or Perforation Interval	From In Feet	To In Feet	
	295-325	& 105-135	
Was Casing Left Open End? ☐ Yes ☒ No			
Material pvc slotted		Diameter In Inches 5	
Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet	
.025	295	325	
Slot Size	Set From In Feet	To In Feet	
.025	105	135	
Was Packer Or Seal Used? ☐ Yes ☒ No			
If So, What Material		Depth In Feet	
Type Of Well ☐ Straight Screen ☒ Gravel Packed		DATE COMPLETED May 29, 2026	
Depth Grouted	From	WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No	
10	40	If So, How	
Grouting Material	Cement	REMARKS	
xx		7G10 1 HP 230 volt pump set at 300 ft.	
If Other, Explain: bentonite chips		DRILLER'S CERTIFICATION	
Well Head Completion: Pitless Unit xx		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.	
12" Above Grade		Driller's Or Firm's Name Dennis Water Well Drilling, Inc.	
Other (Specify)		Certificate Number 61	
It Other, Specify		Address 10240 Highway 10, Gladstone, ND 58630-9530	
		Signed By James E. Dennis	
		Date June 3, 2026	