STATE OF NORTH DAKOTA

BOARD OF WATER WELL CONTRACTORS

900 E. BOULEVARD AVE. DEPT. 770 • BISMARCK, NORTH DAKOTA 58505-0850

WELL DRILLER'S REPORT

RECEIVED
AUG 21 2026
ND DEPT. OF WATER RESOURCES

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

1. WELL OWNER

Name: Schenik LLC

Address: PO Box 608
Parshall, ND 58770

2. WELL LOCATION

Sketch map location must agree with written location.

GPS
47.97039 N
102.25664 W

EL 1886

15209019CBB

NORTH

1 MILE

Sec. (1 mile)

County: Mountrail

NW 1/4 NW 1/4 SW 1/4 Sec. 19 Twp. 152 N. Rg. 090 W.

3. PROPOSED USE

☐ Domestic ☐ Stock ☐ Geothermal ☐ Irrigation ☐ Municipal ☐ Monitoring ☒ Industrial ☐ Test Hole

4. METHOD DRILLED

☐ Cable ☒ Forward Rotary ☐ Reverse Rotary ☐ Jetted ☐ Bored ☐ Auger

If other, specify:

5. WATER QUALITY

Was a water sample collected for:

Chemical Analysis? ☐ Yes ☐ No

Bacteriological Analysis? ☐ Yes ☐ No

If so, to what laboratory was it sent?

6. WELL CONSTRUCTION

Diameter of hole 22 inches. Depth 110 feet.

Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Threaded ☒ Welded ☐ Other

If other, specify:

Pipe Weight:	Diameter:	From:	To:
SDR 26 lb/ft	16 inches	+1 feet	68 feet
____ lb/ft	____ inches	____ feet	____ feet
____ lb/ft	____ inches	____ feet	____ feet

Was perforated pipe used? ☐ Yes ☒ No

Perforated pipe set from ____ ft. to ____ feet

Was casing left open end? ☐ Yes ☒ No

Was a well screen installed? ☒ Yes ☐ No

Material Stainless steel Diameter 16 inches

Slot Size 1080 set from 68 feet to 108 feet

Slot Size ____ set from ____ feet to ____ feet

Was packer or seal used? ☐ Yes ☒ No

If so, what material ____ Depth ____ ft.

Type of well: Straight screen ☐ Gravel packed ☒

Depth grouted: From 0 To 30

Grouting Material: Cement ____ Other X

If other, explain: High Solids Bentonite Grout

Well head completion: Pitless unit ____

12" above grade X Other ____

If other, specify:

Was pump installed? ☒ Yes ☐ No

Was well disinfected upon completion? ☒ Yes ☐ No

7. WATER LEVEL

Static water level 78 feet below surface

If flowing: closed-in pressure ____ psi

GPM flow ____ through ____ inch pipe

Controlled by: ☐ Valve ☐ Reducers ☐ Other

If other, specify:

8. WELL TEST DATA

☒ Pump ☐ Bailer ☐ Other

Pumping level below land surface:

44 ft. after 24 hrs. pumping 945 gpm

____ ft. after ____ hrs. pumping ____ gpm

____ ft. after ____ hrs. pumping ____ gpm

9. WELL LOG

Formation	Depth (ft.) From	Depth (ft.) To
Top Soil	0	2
		2
yellow clay	2	18
oxidiziade sand	18	28
Blue clay	28	64
Sand + Gravel	64	108

(Use separate sheet if necessary)

10. DATE COMPLETED 8-2-26

11. WAS WELL PLUGGED OR ABANDONED?

☐ Yes ☒ No

If so, how:

12. REMARKS:

13. DRILLER'S CERTIFICATION

This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Mazikowski Well Drilling Inc 50

Driller's or Firm's Name — License No

Lidgerwood ND 58053

Address

By [signature] 8/14/26

Signed by — Date

WHITE-DRILLER'S COPY YELLOW-BOARD'S COPY PINK-CUSTOMER'S COPY