



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED
AUG 17 2026
ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name <i>Gene Larson</i>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <i>York ND</i>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>15</i>			
County <i>Burton</i> GPS <i>48.15489</i> <i>99.34408</i> 1/4 <i>NW</i> 1/4 <i>SE</i> 1/4 <i>SW</i> Township <i>156 N</i> Range <i>68 W</i> Section <i>20</i>				If Flowing, Closed-In Pressure In PSI			
				GPM Flow <i>10</i> Through <i>1"</i> Inch Pipe			
				Controlled By ☒ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____			
PROPOSED USE <i>15606813CDB</i>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.) From To			
WELL CONSTRUCTION				<i>Fill yellow clay</i> <i>0</i> <i>20</i>			
Diameter Of Hole In Inches <i>8 3/4</i> Depth In Feet <i>50</i>				<i>Grey clay peckly sand</i> <i>20</i> <i>40</i>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____				<i>Grey clay peckly sand</i> <i>40</i> <i>60</i>			
Pipe Weight	Diameter	From	To				
lb/ft	inches <i>5</i>	feet <i>1</i>	feet <i>30</i>				
lb/ft	inches	feet	feet				
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
Was Casing Left Open End? ☐ Yes ☒ No							
Material <i>PVC</i>	Diameter In Inches <i>5"</i>						
Slot Size <i>20</i>	Set From In Feet <i>20</i>	To In Feet <i>50</i>					
Slot Size	Set From In Feet	To In Feet					
Was Packer Or Seal Used? ☐ Yes ☒ No							
If So, What Material		Depth In Feet					
Type Of Well ☐ Straight Screen ☒ Gravel Packed							
Depth Grouted	From <i>0</i>	To <i>10</i>					
Grouting Material	Cement	Other <i>T</i>					
If Other, Explain: <i>Red flint sand</i>							
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <i>Harmon Water Well</i> Certificate Number <i>202</i>			
				Address <i>Rubicon ND</i>			
				Signed By <i>Wagner</i> Date <i>8-11-20</i>			