



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

AUG 13 2026

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND 58504

State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name <u>Gabe ERBELE</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>6471 51st Ave SE</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>Pumping static</u>			
		County <u>Logan</u>		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4 <u>46-28'</u>	1/4 <u>23-7"</u>	1/4 <u>N</u>	GPM Flow Through Inch Pipe		
		Township <u>99-21'</u>	Range <u>07-9"</u>	Section <u>12</u>	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____		
PROPOSED USE <u>13506928DDA</u>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☒ Pump ☐ Bailer ☐ Other			
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After <u>100</u> Hrs. Pumping <u>2 Hours</u> <u>28</u> GPM			
☐ Cable ☐ Jetted ☐ Forward Rotary ☐ Reverse Rotary				Feet After _____ Hrs. Pumping _____ GPM			
☐ Bored ☐ Auger ☐ If Other, Specify _____				Feet After _____ Hrs. Pumping _____ GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☒ Yes ☐ No				Formation Depth (ft.)			
Bacteriological Analysis? ☒ Yes ☐ No				From To			
If So, To What Laboratory Was It Sent?				<u>TOPSOIL</u> <u>0</u> <u>2</u>			
WELL CONSTRUCTION				<u>Brown sandy clay</u> <u>2</u> <u>18</u>			
Diameter Of Hole In Inches <u>7 7/8</u>		Depth In Feet <u>136'</u>		<u>Small gravel</u> <u>18</u> <u>19</u>			
Casing:		☐ Steel ☒ Plastic ☐ Concrete ☐ Other		<u>gray clay, very soft</u> <u>19</u> <u>56</u>			
☐ Threaded ☐ Welded		☐ If Other, Specify _____		<u>gray sandy clay</u> <u>56</u> <u>118</u>			
Pipe Weight	Diameter	From	To	<u>sand stone</u> <u>118</u> <u>119</u>			
<u>sch 40</u> lb/ft	<u>4</u> inches	<u>0</u> feet	<u>116</u> feet	<u>Small gravel/course sand</u> <u>119</u> <u>135</u>			
lb/ft	inches	feet	feet	<u>Brown sandy clay</u> <u>136</u>			
lb/ft	inches	feet	feet				
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval	From In Feet	To In Feet					
<u>20'</u>	<u>116</u>	<u>136'</u>					
Was Casing Left Open End? ☐ Yes ☒ No							
Material <u>PVC sch 40</u>		Diameter In Inches <u>4</u>		Use Separate Sheet If Necessary			
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED <u>Aug 6, 2026</u>			
<u>16</u>	<u>116</u>	<u>136</u>		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☐ No			
Slot Size	Set From In Feet	To In Feet		If So, How			
				REMARKS			
Was Packer Or Seal Used? ☐ Yes ☐ No							
If So, What Material		Depth In Feet					
Type Of Well ☐ Straight Screen ☒ Gravel Packed <u>#40 sand</u>							
Depth Grouted	From	To					
<u>medium chips</u>	<u>80'</u>	<u>105'</u>					
Grouting Material	Cement	Other					
	<u>10'</u>	<u>40'</u>					
If Other, Explain:							
Well Head Completion: Pitless Unit <u>yes</u>				DRILLER'S CERTIFICATION			
12" Above Grade <u>yes</u>		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>Northern plains Drilling</u> Certificate Number <u>127</u>			
				Address <u>4007 State St</u>			
				Signed By <u>[Signature]</u> Date <u>8-10-26</u>			