WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED
AUG 10 2026
ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER
Name: Gérard wald
Address: 9070 Hwy 3 SE Wishek ND

WELL LOCATION
Sketch map location must agree with written location.

County: McIntosh | GPS: on Bottom
1/4 | 1/4 | 1/4
Township | Range | Section

PROPOSED USE
13007114BAD
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole

METHOD DRILLED
☒ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary
☐ Bored ☐ Auger ☐ If Other, Specify

WATER QUALITY
Was a water sample collected for
Chemical Analysis? ☐ Yes ☒ No
Bacteriological Analysis? ☐ Yes ☒ No
If So, To What Laboratory Was It Sent?

WELL CONSTRUCTION
Diameter Of Hole In Inches: 7 7/8 | Depth In Feet: 48'
Casing:
☐ Steel ☒ Plastic ☐ Concrete ☐ Other
☐ Threaded ☐ Welded ☐ If Other, Specify

Pipe Weight	Diameter	From	To
lb/ft SCH 40	inches 4"	feet 0	feet 38
lb/ft	inches	feet	feet
lb/ft	inches	feet	feet

Was A Well Screen Installed? ☒ Yes ☐ No
Was Perforated Pipe Used? ☐ Yes ☒ No

Screen Or Perforation Interval	From In Feet	To In Feet
20 SLOT	38	48

Was Casing Left Open End? ☐ Yes ☒ No

Material	Diameter In Inches
PVC SCH 40	46

Slot Size	Set From In Feet	To In Feet
20 SLOT	38	48
Slot Size	Set From In Feet	To In Feet

Was Packer Or Seal Used? ☐ Yes ☒ No

If So, What Material	Depth In Feet

Type Of Well: ☒ Straight Screen ☐ Gravel Packed — PEA GRAVEL

Depth Grouted	From	To
	20	0
Grouting Material	Cement	Other

If Other, Explain: MEDIUM CHIPS
Well Head Completion: Pitless Unit

12" Above Grade	Other (Specify)

It Other, Specify

Was Pump Installed? ☐ Yes ☒ No
Was Well Disinfected Upon Completion? ☒ Yes ☐ No

WATER LEVEL
Static Water Level (In Feet) Below Surface: 0
If Flowing, Closed-In Pressure In PSI: WELL IS FLOWING LESS THAN 1 GPM
GPM Flow | Through | Inch Pipe
Controlled By ☐ Valve ☐ Reducers ☐ Other
☐ If Other, Specify

WELL TEST DATA
☒ Pump ☐ Bailer ☐ Other
Pumping Level Below Land Surface

Feet After	Hrs. Pumping	GPM
48	OVER 2	3
Feet After	Hrs. Pumping	GPM
Feet After	Hrs. Pumping	GPM

WELL LOG

Formation	Depth (ft.) From	To
TOP SOIL	0	2
BROWN CLAY	2	18
GREY CLAY	18	38
GREEN BLUE SANDY CLAY	38	44
BLUE BLACK SAND, VERY FINE	44	48

Use Separate Sheet If Necessary

DATE COMPLETED: 7/28/2026
WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No
If So, How

REMARKS
GPS - 46° 04' 59.7" N
99° 32' 06.2" W

DRILLER'S CERTIFICATION
This well was drilled under my jurisdiction and this report is true to the best of my knowledge.

Driller's Or Firm's Name	Certificate Number
NORTHERN PLAINS DRILLING	127

Address: 4007 STATE ST SUITE 40 BISMARCK ND
Signed By: [signature] | Date: Aug 4-26

COPY FOR BOARD | COPY FOR DRILLER | COPY FOR CUSTOMER