



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

AUG 25 2026

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name <u>Gabe Erbele</u>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <u>6471 51st Ave SE Lehn</u>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <u>11'</u>			
County <u>Logan</u> GPS <u>On Bottom</u> 1/4 1/4 1/4 Township Range Section				If Flowing, Closed-In Pressure In PSI			
				GPM Flow Through Inch Pipe			
				Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify			
PROPOSED USE <u>13506934BCB</u>				WELL TEST DATA			
☒ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				☒ Pump ☐ Bailer ☐ Other			
METHOD DRILLED				Pumping Level Below Land Surface			
☒ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify				Feet After <u>205'</u> Hrs. Pumping <u>3</u> GPM <u>3</u>			
WATER QUALITY Was a water sample collected for				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☐ Yes ☒ No				Feet After Hrs. Pumping GPM			
Bacteriological Analysis? ☐ Yes ☒ No				WELL LOG			
If So, To What Laboratory Was It Sent?				Formation Depth (ft.)			
WELL CONSTRUCTION				From To			
Diameter Of Hole In Inches <u>7 7/8</u> Depth In Feet <u>207'</u>				<u>Brown sand / small gravel</u> <u>0</u> <u>6</u>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify				<u>Brown sandy clay</u> <u>6</u> <u>22</u>			
Pipe Weight Diameter From To				<u>coarse sand / gravel</u> <u>22</u> <u>55</u>			
<u>Sch 40</u> <u>4</u> <u>0</u> <u>177</u>				<u>sand stone</u> <u>55</u> <u>56</u>			
lb/ft inches feet feet				<u>gray clay</u> <u>56</u> <u>161</u>			
lb/ft inches feet feet				<u>gray sandy clay</u> <u>161</u> <u>182</u>			
lb/ft inches feet feet				<u>sand stone</u> <u>182</u> <u>183</u>			
				<u>blue / black sand</u> <u>183</u> <u>203</u>			
				<u>small gravel</u> <u>203</u> <u>207</u>			
Was A Well Screen Installed? ☒ Yes ☐ No							
Was Perforated Pipe Used? ☐ Yes ☒ No							
Screen Or Perforation Interval From In Feet To In Feet							
<u>20'</u> <u>177</u> <u>207</u>							
Was Casing Left Open End? ☐ Yes ☒ No							
Material <u>plc sch 40</u> Diameter In Inches <u>4</u>							
Slot Size Set From In Feet To In Feet				Use Separate Sheet If Necessary			
<u>16</u> <u>177</u> <u>207</u>							
Slot Size Set From In Feet To In Feet				DATE COMPLETED <u>8-12-26</u>			
Was Packer Or Seal Used? ☐ Yes ☐ No				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☐ No			
If So, What Material Depth In Feet				If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed <u>#40 slot</u>				REMARKS			
Depth Grouted From To				<u>46° 28' 02.9"</u>			
<u>medium chips</u> <u>105'</u> <u>70'</u>				<u>99° 20' 26 56.1"</u>			
Grouting Material Cement Other							
<u>medium chips</u> <u>60'</u> <u>20'</u>							
If Other, Explain:							
Well Head Completion: Pitless Unit <u>NO</u>				DRILLER'S CERTIFICATION			
12" Above Grade Other (Specify)				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Driller's Or Firm's Name <u>Northern Plains Drilling</u> Certificate Number <u>127</u>			
				Address <u>4007 State St Suite 40</u>			
				Signed By <u>[Signature]</u> Date <u>8-19-26</u>			