




SEP 04 2026

ND Board of Water Well Contractors • 900 E. Boulevard Ave. - Dept. 770 • Bismarck, ND, 58505-0850
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☒ Yes ☐ No			
Name Kadmas, Daryl				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address 350 8th Ave., PO Box 206, Gladstone, ND 58630				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface 15			
	County Stark		GPS		If Flowing, Closed-In Pressure In PSI		
	1/4 SE	1/4 NW	1/4 NW		GPM Flow Through Inch Pipe		
Township 13N	Range 9E		Section 17		Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify _____		
PROPOSED USE I3909417BBD				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial ☐ Stock ☒ Irrigation ☐ Monitoring ☐ Test Hole				☐ Pump ☐ Bailer ☒ Other air compressor			
METHOD DRILLED				Pumping Level Below Land Surface			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary ☐ Bored ☐ Auger ☐ If Other, Specify _____							
WATER QUALITY Was a water sample collected for?				Feet After Hrs. Pumping GPM			
Chemical Analysis? ☒ Yes ☐ No				73 1 4.5			
Bacteriological Analysis? ☒ Yes ☐ No				Feet After Hrs. Pumping GPM			
If So, To What Laboratory Was It Sent? by owner				Feet After Hrs. Pumping GPM			
WELL CONSTRUCTION				WELL LOG			
Diameter Of Hole In Inches 10		Depth In Feet 106		Formation		Depth (ft.) From To	
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other ☐ Threaded ☐ Welded ☐ If Other, Specify _____	Pipe Weight 200 lb/ft	Diameter 5 inches	From 0 feet	To 68 feet	topsoil 0 1		
	lb/ft	inches	feet	feet	brown sand 1 10		
	lb/ft	inches	feet	feet	fine blue sand 10 20		
	lb/ft	inches	feet	feet	gray shale 20 68		
Was A Well Screen Installed? ☒ Yes ☐ No				fine gray sand, sandy clay 68 102			
Was Perforated Pipe Used? ☒ Yes ☐ No				gray shale 102 120			
Screen Or Perforation Interval	From In Feet 68	To In Feet 102					
Was Casing Left Open End? ☐ Yes ☒ No							
Material pvc slotted		Diameter In Inches 5		Use Separate Sheet if Necessary			
Slot Size .025	Set From In Feet 68	To In Feet 102					
Slot Size	Set From In Feet	To In Feet		DATE COMPLETED August 8, 2026			
Was Packer Or Seal Used? ☒ Yes ☐ No				THIS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
If So, What Material steel/rubber	Depth In Feet 82		If So, How				
Type Of Well ☐ Straight Screen ☒ Gravel Packed	REMARKS						
Depth Grouted From To 0 50	7G07 3/4 HP 230 volt 3 wire pump Pump setting - 75 ft.						
Grouting Material Cement Other							
If Other, Explain: bentonite chips				DRILLER'S CERTIFICATION			
Well Head Completion-Drill Unit				This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
12" Above Grade XX		Other (Specify)		Driller's Or Firm's Name Dennis Water Well Drilling, Inc.		Certificate Number 61	
If Other, Specify				Address 3645 102G Ave SW, Gladstone, ND 58630		Signed By James E. Dennis	
				Date September 1, 2026			

COPY FOR BOARD

COPY FOR DRILLER

COPY FOR CUSTOMER