



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

SEP 03 2026

ND DEPT. OF WATER RESOURCES

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No					
Name <i>Jeremiah Blahna</i>				Was Well Disinfected Upon Completion? ☐ Yes ☒ No					
Address <i>Campston ND</i>				WATER LEVEL					
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>12.6</i>					
		County <i>Foster</i>		GPS		If Flowing, Closed-In Pressure In PSI			
		1/4 <i>47.44520</i>		1/4 <i>98.84557</i>		GPM Flow <i>10-15</i> Through <i>air</i> Inch Pipe			
		Township		Range		Section		Controlled By ☐ Valve ☐ Reducers ☐ Other	
								☐ If Other, Specify	
PROPOSED USE <i>14606420 DDB</i>				WELL TEST DATA					
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☐ Pump ☐ Bailer ☐ Other					
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface					
METHOD DRILLED				Feet After Hrs. Pumping GPM					
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After Hrs. Pumping GPM					
☐ Bored ☐ Auger ☐ If Other, Specify				Feet After Hrs. Pumping GPM					
WATER QUALITY Was a water sample collected for				WELL LOG					
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)					
Bacteriological Analysis? ☐ Yes ☒ No				From To					
If So, To What Laboratory Was It Sent?				<i>Top Soil</i> <i>0</i> <i>1 1/2</i>					
WELL CONSTRUCTION				<i>Clay Sand</i> <i>1 1/2</i> <i>12</i>					
Diameter Of Hole In Inches <i>8 3/4</i>		Depth In Feet <i>45</i>		<i>Sand Gravel</i> <i>12</i> <i>20</i>					
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other				<i>Sand</i> <i>20</i> <i>36</i>					
☐ Threaded ☐ Welded ☐ If Other, Specify				<i>Shale</i> <i>36</i> <i>40</i>					
Pipe Weight	Diameter	From	To	<i>Shale</i> <i>40</i> <i>60</i>					
lb/ft <i>21</i>	inches <i>5</i>	feet <i>1</i>	feet <i>30</i>	<i>Shale</i> <i>60</i> <i>80</i>					
lb/ft	inches	feet	feet	<i>Shale</i> <i>80</i> <i>100</i>					
lb/ft	inches	feet	feet						
Was A Well Screen Installed? ☒ Yes ☐ No									
Was Perforated Pipe Used? ☐ Yes ☒ No									
Screen Or Perforation Interval		From In Feet	To In Feet						
Was Casing Left Open End? ☐ Yes ☒ No									
Material <i>PVC</i>		Diameter In Inches <i>5</i>		Use Separate Sheet If Necessary					
Slot Size <i>25</i>	Set From In Feet <i>30</i>	To In Feet <i>45</i>		DATE COMPLETED <i>Aug 2026</i>					
Slot Size	Set From In Feet	To In Feet		WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No					
Was Packer Or Seal Used? ☐ Yes ☒ No				If So, How					
If So, What Material		Depth In Feet		REMARKS					
Type Of Well ☐ Straight Screen ☒ Gravel Packed									
Depth Grouted		From <i>0</i>	To <i>15</i>						
Grouting Material		Cement	Other <i>X</i>						
If Other, Explain: <i>Chaos Pea Rock</i>									
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION					
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.					
It Other, Specify				Drillers Or Firm's Name <i>Robinson Water Well</i> Certificate Number <i>202</i>					
				Address <i>Robinson ND</i>					
				Signed By <i>Robinson</i> Date <i>8-26-26</i>					