



WELL DRILLER'S REPORT
NORTH DAKOTA BOARD OF WATER WELL CONTRACTORS
STATE OF NORTH DAKOTA
SFN 60273 (8/2023)

RECEIVED

SEP 03 2026

ND Board of Water Well Contractors • 1200 Memorial Highway • Bismarck, ND, 58504 ND DEPT. OF WATER RESOURCES
State law requires that this report be filed with the State Board of Water Well Contractors within 30 days after completion or abandonment of the well.

WELL OWNER				Was Pump Installed? ☐ Yes ☒ No			
Name <i>Ryan Topp</i>				Was Well Disinfected Upon Completion? ☒ Yes ☐ No			
Address <i>Canyon</i>				WATER LEVEL			
WELL LOCATION Sketch map location must agree with written location.				Static Water Level (In Feet) Below Surface <i>90</i>			
		County <i>Stutsman</i>		GPS		If Flowing, Closed-In Pressure In PSI	
		1/4	1/4	1/4	GPM Flow <i>50</i> Through <i>air</i> Inch Pipe		
		Township		Range	Section	Controlled By ☐ Valve ☐ Reducers ☐ Other ☐ If Other, Specify	
PROPOSED USE <i>14406512DAC</i>				WELL TEST DATA			
☐ Domestic ☐ Geothermal ☐ Municipal ☐ Industrial				☐ Pump ☐ Bailer ☐ Other			
☒ Stock ☐ Irrigation ☐ Monitoring ☐ Test Hole				Pumping Level Below Land Surface			
METHOD DRILLED				Feet After Hrs. Pumping GPM			
☐ Cable ☐ Jetted ☒ Forward Rotary ☐ Reverse Rotary				Feet After Hrs. Pumping GPM			
☐ Bored ☐ Auger ☐ If Other, Specify				Feet After Hrs. Pumping GPM			
WATER QUALITY Was a water sample collected for				WELL LOG			
Chemical Analysis? ☐ Yes ☒ No				Formation Depth (ft.)			
Bacteriological Analysis? ☐ Yes ☒ No				From To			
If So, To What Laboratory Was It Sent?				<i>TOP Soil</i> <i>0</i> <i>2</i>			
WELL CONSTRUCTION				<i>Dry Sand Rock</i> <i>2</i> <i>10</i>			
Diameter Of Hole In Inches <i>8 3/4</i>		Depth In Feet <i>219</i>		<i>Sand Rock Gravel</i> <i>10</i> <i>20</i>			
Casing: ☐ Steel ☒ Plastic ☐ Concrete ☐ Other				<i>" Clay "</i> <i>20</i> <i>26</i>			
☐ Threaded ☐ Welded ☐ If Other, Specify				<i>" "</i> <i>26</i> <i>40</i>			
Pipe Weight	Diameter	From	To	<i>" "</i> <i>40</i> <i>60</i>			
lb/ft	inches <i>5</i>	feet <i>1</i>	feet <i>179</i>	<i>" "</i> <i>60</i> <i>80</i>			
lb/ft	inches	feet	feet	<i>" "</i> <i>80</i> <i>100</i>			
lb/ft	inches	feet	feet	<i>Clay Sand</i> <i>100</i> <i>120</i>			
Was A Well Screen Installed? ☒ Yes ☐ No				<i>Clay Sand</i> <i>120</i> <i>140</i>			
Was Perforated Pipe Used? ☐ Yes ☒ No				<i>Sand Clay</i> <i>140</i> <i>160</i>			
Screen Or Perforation Interval	From In Feet	To In Feet		<i>Sand Clay</i> <i>160</i> <i>180</i>			
Was Casing Left Open End? ☐ Yes ☒ No				<i>Sand Shale</i> <i>180</i> <i>200</i>			
Material <i>Plastic</i>	Diameter In Inches <i>5</i>			<i>Sand Shale</i> <i>200</i> <i>220</i>			
Slot Size <i>20</i>	Set From In Feet <i>179</i>	To In Feet <i>199</i>		Use Separate Sheet If Necessary			
Slot Size <i>25</i>	Set From In Feet <i>199</i>	To In Feet <i>219</i>		DATE COMPLETED <i>Aug 2026</i>			
Was Packer Or Seal Used? ☐ Yes ☒ No				WAS WELL PLUGGED OR ABANDONED? ☐ Yes ☒ No			
If So, What Material		Depth In Feet		If So, How			
Type Of Well ☐ Straight Screen ☒ Gravel Packed				REMARKS			
Depth Grouted	From <i>0</i>	To <i>45</i>					
Grouting Material	Cement	Other					
If Other, Explain: <i>Chips Per Rock</i>							
Well Head Completion: Pitless Unit				DRILLER'S CERTIFICATION			
12" Above Grade		Other (Specify)		This well was drilled under my jurisdiction and this report is true to the best of my knowledge.			
It Other, Specify				Drillers Or Firm's Name <i>Robbie Water</i>		Certificate Number <i>202</i>	
				Address <i>Robbie Water</i>		Signed By <i>Robbie Water</i>	
				Date <i>8-17-26</i>			